MECKLENBURG COUNTY
Health Department

Gibbie Harris
Health Director

(704) 336-4700

February 13, 2018

CAROLYN GASKIN
2639 COLTON DR
Charlotte, NC 28278

Re: Application for approval to use an existing on-site wastewater treatment & disposal system.
Property Location: 15500 Walnut Hill Dr., Charlotte, NC
Health Department File Number: **8116B**

Dear Property Owner or Owner's Agent:

On January 22, 2018 the Mecklenburg County Health Department, Groundwater & Wastewater Services Section, evaluated the above-referenced property to determine if approval to use an existing on-site wastewater treatment & disposal system could be granted for your proposed project. This evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 130A-333 and related statutes, Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule .1900 and related rules, and the Mecklenburg County Groundwater Well Regulations.

Will require consultant or hook to public utilities for any design greater than 240 gpd

Based on the information provided in the application, dated January 22, 2018, and findings from the site evaluation conducted by our office, your request for approval to use an existing on-site wastewater treatment & disposal system is **not** being granted. This decision is based on the following conditions that were identified during the site visit:

- ☐ The existing on-site wastewater treatment & disposal system was not functioning properly at the time the site evaluation was conducted.
- ☐ The proposed plans do not meet the required setbacks for the on-site wastewater treatment & disposal system serving the property.
- ☐ The proposed plans do not meet the required setbacks for the reserved repair area for an on-site wastewater treatment & disposal system.
- ☒ The proposed plans do not meet the required setbacks for water supply wells.
- The proposed project will exceed the permitted daily design flow for the existing on-site wastewater treatment & disposal system. System alteration will be required in order to accommodate your proposed project.

If you need any additional information or assistance please contact our office at (704) 336-5103.

Sincerely,

Bradley W Hallman, REHS
Sr.Environmental Specialist