Date Received 7-20-73

(55)

MECK COUNTY HEALTH DEPT.
RECEIVED
JUL 2 - 1973

APT No. 6204
T. C No. 101-242-22
Map Date 6 10 74

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Lutz Const. Co. Inc
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 1319 Commercial Ave ZIP 28205

3) PHONE NO. Home _____ Office 375-7112


4) LOCATION OF PROPERTY 7151 Hunsucker Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Kenilworth LOT NO. 8 BLOCK NO. 4

MAP BOOK NO 15 PAGE NO. 585

6) DEED REFERENCE DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Bruce Lutz
OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

Serial No. 3482

PTR No. 6704

T C No 109-242-22

Date Issued August 15, 1973

Map Date 12-15-72 0 10 74

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Gettys Construction Company, Inc.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 1319 Commerical Avenue ZIP 28205

LOCATION OF PROPERTY 7151 Chapparall Lane
(STREET OR COUNTY ROAD)

SUBDIVISION Ravenwood LOT NO 8 BLOCK NO. 4



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot

The percolation rate determined by the test was 55 min/in The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater teratment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John R. Johnson

Director, Environmental Health Division or
Authorized Section Head

FORM NO. E-2-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 8 17 73

SEE INSTRUCTIONS ON BACK

MECK COUNTY HEALTH DEPT
RECEIVED
AUG 1 1973
ENVIRONMENTAL HEALTH DIVISION

MECK COUNTY HEALTH DEPT
RECEIVED
1973
ENVIRONMENTAL HEALTH DIVISION

YEAR(S) Application No. 6704

T. C No. ~~AG-XX-XX~~

Map Date 4-15-73 107-242-22 & 10-19

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


Application for an

Installation, Construction, Alteration, and/or Repair Permit

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1) ✓ Install or Construct 2) ~~X~~ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No. of Bedrooms 3

5) Business Use — Max No Employees _____

6) Washing Machine ✓ Yes ___ No

7) Garbage Disposal ___ Yes ✓ No

8) Dishwasher ___ Yes ✓ No

9) Water Supply:
A) Individual Well ✓
B) Governmental System ___
C) Community System:
1. Well source ___
2. Governmental source ___

10) Sewage System:
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No

11) FHA Case No. ~~XXX~~

12) VA Case No. ~~XX~~

13) NAME OF OWNER Gutter Const. Co. Inc
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 1319 Communical Ave

15) PHONE NO. Home _____ Office 375-7112

16) LOCATION OF SYSTEM 7151 Wilkinson Blvd
STREET OR COUNTY ROAD

17) SUBDIVISION Commercial Lot No. 8 Block No. 4

Map Book No 15 Page No. 585

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN 8 15 73 RD 55

20) PTR NUMBER (See Instructions) 6704

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

5-15-73
DATE OF APPLICATION

Brian Gutter
OWNER

FORM NO. E-4-4-1-71

HEALTH DEPARTMENT'S COPY

Serial No. 3310

LA No. 6704

Date Issued August 17, 1973

T C No. 107-242-22

Map Date 12-26-72
0-10-74

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Gettys Construction Company, Inc.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 1319 Commerical Avenue ZIP _____

LOCATION OF LOT 7151 Chapparall Lane
(STREET OR COUNTY ROAD)

SUBDIVISION Ravenwood LOT NO. 8 BLOCK NO. 4

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 55 min/in on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 6704. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

B.M Reynolds
Environmentalist

John R Adkisson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 22Mar74 Serial No. 5017 ICAR(S) Permit No 6704

T C No ~~106-242-08~~ 107-242-02

Map Date 12-15-72

6-10-74


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct. Alter or Repair the individual septic tank waste water treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 6704 dated 8-15-73 and this permit shall be void and of no effect if the information provided in the application is not correct or is erroneous. All work shall be completed on or before 22Apr74 after which date this permit shall be null and void



Percolation Rate 55

Liquid Capacity of Tank 1000 gal

Tank Construction Precast Concrete

Absorption and/or Nitrification Lines

Total Line Length 400' & 150'

Number of Lines Two Beds 10'X50'

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

TYPE OF SYSTEM

NAME OF OWNER Getty's Const. Co. Inc.

LOCATION OF PROPERTY 7151 Chapparall Lane

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments aeration pit 2½'X7'X4' stone

Division or Section Head

R. M. Reynolds
Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired

REV. 5 E-5-9-1-72

Serial 4555

C of A (s) No. 6704

Date Issued 22Mar74

T C No 106-242-08

Map Date 12-15-72 109-242 22

6-10-74

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Getty's Concrete Co. (LAST, FIRST, MIDDLE)

Location of Property 7151 Capparall Lane

Application Number 6704 Permit Number 6704

Inspection Data:

Liquid Capacity of Tank 6704 Tank Material 6704

Total Length of Drain Tile 400' & 150' Number of Lines Two Beds (4) 10' x 50'

Depth of Filter Material 17" Cover Depth 24"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 22Mar74 (DATE) Tank Inspected 22Mar74 (DATE)

Nitrification Field Inspected 22Mar74 (DATE)

Washing Machine Line Inspected, If Applicable 22Mar74 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, ~~altered~~ or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: aeration pit O.K.

B.M. Reynolds
Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY

T. C. No. 031-103-5[illegible]

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

MECK. COUNTY HEALTH DEPT.
RECEIVED
JUN [illegible] 1974
Well Permit No. 6705
ENVIRONMENTAL HEALTH DIVISION

WELL RECORD

Drilling Contractor Lanier + Hartley Well Drilling No. 129

1. Town Charlotte — County [illegible]
2. Location Pinehurst Country Club, Lot # 27 + 28 Quadrangle No. —
   Show a sketch of location on back of form. Cured 4
3. Owner Lynne Franklin Trust
   Address 4 C's Brooking Rd., Charlotte N.C.
4. Topography: draw, slope, hilltop, valley, flat (Lots 10.9)
5. Use of Well RD Date Completed [illegible]
6. Rig type or method Air Total Depth 145
7. Casing: Depth From 0 to 110 ft. Diam. 6 in. Type 13.00 Galv
8. Grout: Depth From 0 to 20 ft. Material Cement in. Method pumped
9. Screen: Depth From — to — ft. Diam. — in. Type and Opening —
10. Water Zones (depth) 140's 145
11. Static Water Level: 35 ft. above / below top of casing
    which is 14c ft. above land surface. Elev. —
    Date —
12. Yield (gpm) 30 Method of testing Air
13. Pumping Water Level: 35 ft. after — hrs.
    at — gpm.
14. Water Quality Good Temperature (°F) —
15. Well sterilization method HTH
16. Permanent Pump: — Type — Make —
    Installed — Date — By —
    Capacity — (gpm) Hp —
    Intake depth — Airline depth —
17. Remarks: —
    HTH

I do hereby certify that this well record is true and exact.

[signature]
SIGNATURE OF CONTRACTOR OR AGENT

DRILLING LOG

Depth From	Depth To	Formation
0	110	Red soil
110	[illegible]	Red Clay

FORM NO. E-22-9-1-72