Date Received 7/22/77 Apt. No. (S)

Application No. (W) 12782

T. C. No. 227-121-2

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR WELL WATER SUPPLY PERMIT

NAME OF OWNER WRIGHT (LAST) JOHN (FIRST) E. (MIDDLE)

ADDRESS OF OWNER [illegible] ZIP 28212

PHONE NO. Home 535-[illegible] Office [illegible]

LOCATION OF PROPERTY High Ridge Road (STREET OR COUNTY ROAD)


SUBDIVISION [illegible] LOT NO. 7 BLOCK NO. 1

MAP BOOK NO. _____ PAGE NO. _____ FHA LOAN

DEED REFERENCE: DEED BOOK _____ PAGE NO. _____ VA LOAN

WELL CONTRACTOR _____ LICENSE NO. _____

Application is hereby made to the Mecklenburg County Health Department for a permit to drill a water well on the hereinabove described lot to be used as a source of ✓ individual, _____ semi public, or _____ public water supply:



ACCURATELY DIAGRAM & DIMENSION LOT

7/7/77
DATE OF APPLICATION

John E Wright
OWNER
Judith D Wright

Application approved and permit hereby granted

Permit No: 12752

ENVIRONMENTALIST

FORM NO. E-20-5-1-73

HEALTH DEPARTMENT'S COPY

Date Received [illegible]

APT No. 12722

T. C. No. P.O. 227-121-05

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER [illegible] Henry G
LAST FIRST MIDDLE

2) ADDRESS OF OWNER [illegible] ZIP 2820[illegible]

3) PHONE NO Home 532 6454 Office 334 9105


4) LOCATION OF PROPERTY High Rock Rd & Sid Hall Rd
STREET OR COUNTY ROAD

5) SUBDIVISION Pine Valley LOT NO 7 BLOCK NO. 1

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK 3944 PAGE NO [illegible]

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

[illegible]
OWNER

EHD-5-76

Environmental Health Department's Copy

SOIL INVESTIGATION REPORT

Date of Investigation June 29, 1977 APT NO. 12782

Owner H. C Newton

Location of Property High Ridge Rd. Ext & Army Mass Rd Lot 7 Block 1

Soil Suitability Ratings Tax Lot No. PO 227-121-05

Soil Properties	Soil 1	Soil 2	Soil 3	Soil 4
1. Soil Series	Ceu.1		Hollis	
2. Soil Slope	suitable 2-6%		suitable 2-6%	
3. Soil Depth	suitable >48"		suitable >48"	
4. Soil Texture	provisionally suitable clay		unsuitable silt clay	
5. Soil Structure	provisionally suitable blocky		unsuitable massive	
6. Restrictive Horizons	—		—	
7. Soil Drainage	suitable water table >6'		unsuitable perched high water table	
8. Soil Permeability (Percolation Rate)	provisionally suitable moderate 60 min/in.		unsuitable very slow >200 min/in.	
9. Other	—		—	
10. Overall Rating	provisionally suitable		unsuitable	


Recommendations Based on this investigation, the lot was found to have an acceptable area of provisionally suitable soils for installation of a septic tank system. System design should be based on a percolation rate of 60 min/in and should be placed in the area of Ceu1 soils.

See diagram on back

W. Edward Grauert
Soil Scientist

3/16/75
EHD 539

DIAGRAM OF PROPERTY



3/18/75
EHD 539

SEE INSTRUCTIONS ON BACK

Date Received 7/22/77

ICAR(S) Application No 12722

T C No 227-1[illegible]


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The [illegible] that [illegible], described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1. ✓ Install or Construct 2 After or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3. PLOT PLAN (ACCURATELY DIMENSIONED)

4. Mobile Home — Yes — No
5. Business Use — Max No Employees — N/A
6. Washing Machine — ✓ Yes — No
7. Garbage Disposal — Yes — ✓ No
8. Dishwasher — ✓ Yes — No
9. Water Supply
   A. Individual Well — ✓
   B. Governmental System —
   C. Community System —
      1. Well Size —
      2. Governmental Source —
10. Sewage System
    Has a public sewer been located within 200 feet of property? — Yes — ✓ No
    Has a public sewer been located within 200 feet of property? — Yes — ✓ No
11. FHA Case No —
12. VA Case No —

13. NAME OF OWNER Wright (LAST) John (FIRST) Charles (MIDDLE)
14. ADDRESS OF OWNER 4406 Bradwell Ct. Charlotte N.C.
15. PHONE NO Home 535-2026 Office 372-6450
16. LOCATION OF SYSTEM Hwy Ridge Rd. (STREET OR COUNTY ROAD) & Cindy Mac B-Circle
17. SUBDIVISION Sandy Plantation Lot No 7 Block No. 1
    Map Book No — Page No. —
18. DEED REFERENCE — DEED BOOK — AT PAGE —
19. HAS A SOIL INVESTIGATION BEEN RUN? X YES NO DATE RUN 6/30/77
20. PTR NUMBER (See Instructions) 13722

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

John C Wright
OWNER
Faythe D Wright

7/7/77
DATE OF APPLICATION

EHD-S-76

Environmental Health Department's Copy

Serial No. 1044

PTR No. 12782

Date Issued June 30, 1977

T C. No. P.0.227-121-05

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Newson (LAST) Henry (FIRST) C. (MIDDLE)

ADDRESS OF OWNER P.O. Box 6113, Charlotte, NC ZIP 28207

LOCATION OF PROPERTY Corner: High Ridge Rd. Ext. & Gray Moss Road (STREET OR COUNTY ROAD)

SUBDIVISION Providence Plantation LOT NO 7 BLOCK NO 1



PLOT PLAN

This is a report of the preliminary investigation and onsite evaluation was made by the Mecklenburg County Department of Environmental Health for subdivision approval. The soil investigation was conducted on the lot indicated in the above plot. **Provisionally Suitable**

The permeability rate determined by the investigation was **60 min/in.** The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A system which meets the requirements of the Mecklenburg County Department of Environmental Health must be constructed on the lot as the wastewater treatment system on the lot.
2. The plans for the wastewater treatment system which must be approved by the Mecklenburg County Department of Environmental Health must be submitted to the permit issuing agent obtained above, and on the application for which this report is made.
3. The lot must be maintained in the natural state and shall be acceptable for system installation at the time of application for a permit.
4. The approval of the lot for the proposed system is based on the soil investigation performed on the lot which was performed by the Mecklenburg County Department of Environmental Health and the lot was indicated as acceptable for the type of wastewater treatment system and the size of the absorption system for such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system these laws, rules and regulations are changed such that this approval would not have been granted had the newer revised laws, rules and regulations been in effect on the issue date.

Soil Scientist

Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

Date Issued July 22, 1977

Serial No. 1028

LA No. 12782

P.O.
T C. No. 227-121-05

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Wright (LAST) John (FIRST) C. (MIDDLE)

ADDRESS OF OWNER 4806 Beechknoll Court, Charlotte, NC ZIP 28212

LOCATION OF LOT High Ridge Road (STREET OR COUNTY ROAD)

SUBDIVISION Providence Plantation LOT NO 7 BLOCK NO. 1

MAP BOOK NO. PAGE NO

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 12782. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

L. P. Jefferson
Environmentalist

John R. Hutchinson
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Issued 8/1[illegible]

Serial No. 0997


ICAR(S) Permit No. 12782

T C No 227121.05

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, __ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 12782, dated [illegible] and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 12782, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate 1'5"

Liquid Capacity of Tank [illegible] 1500 gal

Tank Construction CC

Absorption and/or Nitrification Lines

Total Line Length 445 (2R) 125

Number of Lines 4 (5)

Distance from House [illegible]

Distance from Property Line [illegible]

Distance from Well [illegible]

NAME OF OWNER [illegible]

LOCATION OF PROPERTY [illegible]

The system shall meet all the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered unaccessible for repair or used. **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

Comments [illegible]

[illegible]

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy