

10736 FOREST DR

19328205

5/10/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

APPLICATION FOR SOIL INVESTIGATION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 3810A

TC: 215-282-05

☐ PC ☐ REPT

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 17 1987
ENVIRONMENTAL HEALTH

JOB LOCATION

① ADDRESS: FOUR LAKES DRIVE & FOREST DRIVE

② SUBDIVISION: MATTHEWS HEIGHTS ③ LOT: 5 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 215 PAGE NO.: 29 PARCEL NO.: 282

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: RUSSELL (FIRST) BARNET (MIDDLE) ISIDOR (LAST)

⑧ MAILING ADDRESS: 1408 FOUR LAKES DRIVE

⑨ CITY: MATTHEWS ⑩ STATE: N.C. ⑪ ZIP: 28105

⑫ PHONE: (WORK) _____ (HOME) 847-4953

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Russell B. Isidor

Date: _____

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY

Department of Environmental Health

September 2nd, 1987

Russell Barnet Isidor
1408 Four Lakes Drive
Matthews, NC 28105

RE: Property located at Four Lakes Drive
FILE: 3810A
PARCEL: 19328205

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 14515) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 14515

File: 3810A Action 4

Parcel: ~~2005218XXX5~~ 19328205 ☐ PC

Location: Four Lakes Drive

Subdivision:


Lot: Block: Acres: .67

Owner: Russell Barnet Isidor
Address: 1408 Four Lakes Drive
Matthews, NC 28105

Comments: _____

Described by: William A. Marlin

Date: 9-2-97



*** EVALUATION KEY ***

S = Suitable U = Unsuitable
PS = *Provisionally Suitable*
The "Area Classification" *below indicates the suitability of areas in the diagram.*

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U >36" TO water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IvA Cecil-like					
Area Classification	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available *without regard* to ethnic origin, sex, or disability.

(OFFICE USE ONLY)

FILE: 3810A

TC: _____

SERIAL: Nº 14456

SEP 14 [illegible]

ENVIRONMENTAL HEALTH DIVISION

☐ L ☒ CRT

JOB LOCATION

① ADDRESS: 10736 (STREET NO.) FOREST DRIVE (STREET) ② FILE: 3810 A

③ JURISDICTION: MATTHEWS ④ TAX PARCEL NO.: 193-282-05

⑤ SUBDIVISION: _____ ⑥ LOT: _____ ⑦ BLOCK: _____

OWNER

⑧ NAME: RUSSELL (FIRST) BARNET (MIDDLE) ISIDOR (LAST)

⑨ MAILING ADDRESS: 1408 FOUR LAKES DRIVE

⑩ CITY: MATTHEWS ⑪ STATE: N.C. ⑫ ZIP: 28105

⑬ PHONE: (WORK) 847-4953 ⑭ (HOME) 847-4953

REQUEST

This request is for a(n):

⑮ ☒ New permit

⑯ ☐ Repair or alteration permit

⑰ ☐ Authorization for mobile home exchange

⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home

㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3

㉕ Type? _____

㉓ Maximum occupancy? 4

㉖ Maximum number of employees? _____

㉔ Basement? ☐ yes ☒ no

㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Russell Barnet Isidor

Date: Sept 14, 1987

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, *certifies that* the Department *has approved* the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal *in effect at the time of issuance* of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit *is issued by this* Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

Environmentalist _____ Date _____

Director or Authorized Section Head [signature] Date 9-15-87

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.

PROPOSED PLOT PLAN


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3810A

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: Laurie Barnett Taylor

Date: Sept 14, 1987