Date Received 4/13/77

APT No. 13844

T. C. No. 011-103-04

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Robinson (LAST) William (FIRST) L (MIDDLE)

2) ADDRESS OF OWNER 727 Beckington Dr ZIP 28213

3) PHONE NO Home 596-7663 Office _____


4) LOCATION OF PROPERTY Poplar Tent Road. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

William L Robinson
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION
(Ground Absorption Sewage Disposal)

APT 13 Bldg H
T E 011-103-01

OWNER: William J. Robinson
ADDRESS: 227 Longtown Cir.
COUNTY: Charlotte N.C.
LOCATION OF SITE: Poplar Tent Road

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 20 plus

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U	(S) PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS (U)	S PS (U)	S PS (U)	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS (U)	S PS (U)	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS U	S PS (U)	S PS (U)	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	(S) PS U	S PS (U)	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS (U)	S PS U	S PS (U)	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS (U)	S PS U	S PS (U)	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	
SOIL SERIES	Helena	Enon- Ult	Chewacla	

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By:

Title: Soil Scientist Date: 5-11-78

DHS Form 2601 (2/77)
Sanitation


Poplar Tent Rd
Exxon-W.Hwy
870'
Drainageway
Chevorle
Helena
272
740
Pipeline

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SIR.NO. 13844
T. C.NO. 011-103-09
MAP DATE -
DATE 5-15-78

NAME OF OWNER Robinson, William L.

ADDRESS OF OWNER 727 Georgetown Drive, Charlotte, N. C. 28213

LOCATION OF LOT Poplar Tent Road

At your request and pursuant to Section. 1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil structure massive
Soil permeability unsuitable

Section 10 of the North Carolina Administrative Code 10A, .1910 of these regulations states "Sites originally classified as unsuitable may be used for soil absorption disposal systems, provided engineering, hydrogeologic, and soils studies indicate to the local agency that a suitable alternate system can reasonably be expected to function satisfactorily.

Section 10, North Carolina Administrative Code 10A, .1916 states that "The design, construction, and maintenance of ground absorption sewage systems, whether septic tank systems or alternate systems shall be the responsibility of the owner, developer. installer, and user of the system as applicable in the circumstances."

We would also advise you that according to Regulation 10, North Carolina Administrative Code 10A, . 1916(b), "Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect compliance with the provisions of this section shall in no way be taken as a guarantee that sewage disposal systems approved and permitted will function in a satisfactory manner for any given period of time or that such employees assume any liability for damages, consequential or direct, which are caused or which may be caused, by a malfunction of such system.

These regulations became effective July 1, 1977. Since that time the second sentence of Section .1910(c) has been found to be nugatory. For this reason, if you desire to file for permission to install an "alternate" system you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R. Adkisson

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section

BID #584

R

STATE OF NORTH CAROLINA Apt 13844 REGISTRATION SEPTIC TANK AGREEMENT
COUNTY OF MECKLENBURG

JUN 26 1 42 PM '78

COPY

The undersigned, William L. Robinson, owner of property located at Poplar Tent Road (Tax Code #011-103-09) ("the site") and described in instrument recorded in Book 3997 at Page 2[illegible] Mecklenburg Public Registry, hereby acknowledges that he applied to the Department of Environmental Health for a permit to install a septic tank sewage disposal system on the site; the Department evaluated the site for suitability for such a system in accord with the regulations promulgated by the North Carolina Commission for Health Services as 10 NCAC 10A .1900 et seq; that the Department classified the site as Unsuitable and an appropriate permit was issued by the Department.

The undersigned further acknowledges that the proper design, construction and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time, or that the Department, its officials, employees or agents assume any liability for damages, consequential or direct, which are caused, or which may be caused, by a malfunction of such system.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the names or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

And the undersigned further agrees for himself, his heirs and assigns, that he shall indemnify and hold harmless the Department and its successors, as well as Mecklenburg County, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure, of said septic tank system.

And the undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately, in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This 26 day of June, 19 78.

William L. Robinson (Seal)

(Seal)

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, Thomas E. Eubanks, a Notary Public for said County and State, do hereby certify that William L. Robinson, personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 26 day of June, 19 78.


Thomas E. Eubanks
Notary Public
My Commission Expires: 1-19-82

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG


I, , a Notary Public for said County and State, do hereby certify that personally came before me this day and acknowledged that he is of , and that by authority duly given and as the act and deed of said corporation, the foregoing instrument was signed in its name by its , sealed with its corporate seal and attested by as its .

WITNESS my hand and notarial seal, this day of , 19 .

Notary Public
My Commission Expires:



5 drain pipe 90' long 3' on center 1150 sq foot bottom area.



15 minimum cover
1 stone over pipe
11 drain pipe
12 under pipe
6 sand

Submitted for consideration and approval:

[illegible] East Rd
Property Location

[illegible] & Katrina
Owner's Signature

Bed System

Date Received

ICAR (S) Application No 13844

T C No. 011-103-09

Map Date 5-15-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) X Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge

3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___Yes ___No
Residence X Yes ___ No
4 No of Bedrooms 3
5 Business Use - Max No Employees ___
6 Washing Machine X Yes ___No
7 Garbage Disposal X Yes ___No
8 Dishwasher X Yes ___No
9 Water Supply
A Individual Well X
B Governmental System ___
C Community System
1 Well source ___
2 Governmental source ___
10 Sewage System
House located within 200 feet of public sewer ___Yes X No
House located within 200 feet of community sewer ___Yes X No
11 FHA Case No ___
12 VA Case No ___

13) NAME OF OWNER [illegible] (LAST) [illegible] (FIRST) [illegible] (MIDDLE)

14) ADDRESS OF OWNER [illegible]

15) PHONE NO Home [illegible] Office ___

16) LOCATION OF SYSTEM [illegible] (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? YES NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION ___

OWNER [signature]

EHD-5-76

Environmental Health Department's Copy

Date Issued 6/30/78 Serial No. 2004

LA No. 13844

T. C. No. 011-103-09

Map Date 5-15-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Robinson (LAST) William (FIRST) L. (MIDDLE)

ADDRESS OF OWNER 727 Georgetown Drive, Charlotte, N. C. ZIP 28213

LOCATION OF LOT Poplar Tent Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 13844. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation Construction, Alteration, and/or Repair Permit be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit ***Agreement card signed and presented for recording on 6/26/78**

Environmentalist

A. M. Reynolds
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Serial No. 4286

ICAR(S) Permit No. 13F44


Date Issued 10-9-70

T C No 011-103-09

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ____Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 13F44, dated 6/16/71 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before _____, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate U.S.

Liquid Capacity of Tank 1500 gal

Tank Construction P.C.

Absorption and or Nitrification Lines

Total Line Length 500' + 125'

Number of Lines 5 + 4

Distance from House 10'

Distance from Property Line 15'

Distance from Well 50'

NAME OF OWNER William F Collins

LOCATION OF PROPERTY 5141 Poplar Tent Church Road.

The system shall meet all the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable if it can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments 36" x 36" [illegible] + 100' + 17' Conc + 6" Sand on Septic System
6" [illegible] 12" x 24" + 17' Conc + 6" Sand on Washing Machine

Foot Walker

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

C of A (s) No. 13844

Date Issued [illegible] **Serial** 4091 T C No [illegible]

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner [illegible] (LAST) [illegible] (FIRST) (MIDDLE)

Location of Property [illegible]

Application Number [illegible] Permit Number [illegible]

Inspection Data:

Liquid Capacity of Tank [illegible] Tank Material [illegible]

Total Length of Drain Tile [illegible] Number of Lines [illegible]

Depth of Filter Material [illegible] Cover Depth [illegible]

Water Supply Source [illegible] Distance from Water Source [illegible]

Excavation Inspected [illegible] (DATE) Tank Inspected [illegible] (DATE)

Nitrification Field Inspected [illegible] (DATE)

Washing Machine Line Inspected, if Applicable [illegible] (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed ______ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments [illegible]

[illegible]

[illegible]

[illegible signature]
Environmentalist

EHD-5-76

Environmental Health Department's Copy