CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21740 DATE: 6-30-89
TC: 139-151-06 ☐ L ☑ CRT
SERIAL № 11971

Name of Owner Richard Heberling Juris.:
Address of Property 14735 Eaglebrook Dr.

Inspection Data:

Tank Material PCC
Total Length of Drainfield 400'
Number of Lines 4 @ 100'
Cover Depth 12"-34"
Water Supply Source well
Distance to Water Source >50'
Excavation Inspected 6-30-89
Tank(s) Inspected 6-30-89
Wash Line Inspected
High Water Alarm Inspected

PLOT

Design: 1989, 1500 ST, con, 1200 SFT, 12.6, Cecil CTR# 177

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☑ installed or constructed ☐ altered or repaired
☑ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☑ Certificate of Completion ☐ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS" This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Installed for 3 bedroom

D. R. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21740 DATE: 6-1-89

PO TC: 139-151-06 ☐ L

SERIAL Nº 12708

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 2-6-89. All work shall be completed on or before 7-1-89, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank _____ gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400 feet

Number of Lines 4

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well ~~not in~~ feet

NAME OF OWNER Richard Heberling

LOCATION OF PROPERTY 14735 Eaglebrook Dr.

Comments: 4 lines 3'x100'x12" stone

Jim Ensein
Division or Section Head

B.R. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

PROPOSED PLOT PLAN

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21740

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: S. Klepfer

Date: 2/6/84

150

APPLICATION FOR AN IMPROVEMENT PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)

FILE: 21740

TC:

SERIAL: № 17725 ☒ L ☒ CRT

JOB LOCATION

① ADDRESS: 11735 (STREET NO) Eaglebrook (STREET) Drive (2) FILE:

③ JURISDICTION: ④ TAX PARCEL NO.:

⑤ SUBDIVISION: Clear Creek Estates ⑥ LOT: 28 (7) BLOCK: II

OWNER

⑧ NAME: Richard (FIRST) — (MIDDLE) Heberling (LAST)

⑨ MAILING ADDRESS: P.O. Box 1891

⑩ CITY: Summerville ⑪ STATE: SC (12) ZIP: 29484

⑬ PHONE: (WORK) 803-766-4031 ⑭ (HOME) 803-821 0551

REQUEST

This request is for a(n):

⑮ ☒ New permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type?

㉓ Maximum occupancy? 5 ㉖ Maximum number of employees?

㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☐ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: [signature]

Date: 2/6/89

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 36 months from the date of issuance.

B.R. Ferguson 2-20-89
Environmental Date

[signature] RS 2-20-89
Director or Authorized Section Head Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date [illegible]

Name/Company [illegible]

Sanitation

Vector Control

O.S.W.D. ✓

Service: [illegible]

[illegible] 21740

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

FEB 6 1969

Fee: $ [illegible]

[illegible]
Completed by

[illegible]
Collected by

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21740

T.C. NO. [illegible]

(Ground Absorption Sewage Disposal)

OWNER: [illegible]
ADDRESS: [illegible]
Charlotte [illegible]

PLAT NO: [illegible]
LOT SIZE: [illegible]

LOCATION OF SITE: Eaglebrook [illegible]

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-10% U	S complex PS slopes U	S PS — U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS clay U	S PS — U	S PS — U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS — U	S PS — U	S PS U
4. SOIL DEPTH (inches)	S PS [illegible] U	S ≤ 36" PS U	S PS — U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S ≥ 36" PS U	S ≤ 36" PS U	S PS — U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S ≥ 36" to PS ground water U	S Eroded PS Areas U Channel runoff	S Drainage-way PS U Depression	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA	—	—	
9. SITE CLASSIFICATION	Provisionally suitable	unsuitable	unsuitable	
10. SOIL SERIES	[illegible]	complex slopes	Drainage-way Depression	

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes

Recommendations/Comments:

Described by: William A. Martin
Title: Soil Scientist

Date: 1-23-85

Serial No. 6027

SIR No. 21740

Date Issued 1-23-85

T. C. No. PO 139-151-06

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Clear Creek Estates, Inc.

ADDRESS OF OWNER (LAST) 1740 E. Independence (FIRST) Blvd., Charlotte, NC (MIDDLE) ZIP 28205

LOCATION OF PROPERTY Coble Road (STREET OR COUNTY ROAD)

SUBDIVISION Clear Creek Estates LOT NO. 28 BLOCK NO. II



PLOT PLAN

This is to certify that a soil investigation and onsite investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. PROVISIONALLY SUITABLE

The permeability rate determined by the investigation was . The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install construct other or repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of construction of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment unit and the minimum installation requirements by the Mecklenburg County Department of Environmental Health shall be predicated primarily upon the data contained above, and on the size and type of building constructed thereon.
3. This approval is valid only for the system as outlined in the above plot plan and shall not be acceptable for system installation on the above plot.
4. This approval is void if any additional [illegible] are encountered in the area in the form of rock, fill dirt, or other [illegible] which in the opinion of the Mecklenburg County Department of Environmental Health is unsuitable for the proposed system installation unless the [illegible] system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the newer revised laws, rules, and regulations been in effect on the issue date.

William H. Mullis
Soil Scientist

Eric D. Hardister
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Issued 8-15-85

Serial No. 8819

SIR No. 21740

T. C. No. PO 139-151-06

Map Date L CET

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
IMPROVEMENT PERMIT
TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Johnson, (LAST) Delano (FIRST) R. (MIDDLE)

ADDRESS OF OWNER 101 Shady Oak Tr., Charlotte, NC ZIP 28210

LOCATION OF LOT 14735 Eaglebrook Drive (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO 28 BLOCK NO. II

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 21740. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Cynthia G. Bass
Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department's Copy

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
JUL 1 [illegible]

(OFFICE USE ONLY)

FILE: 21740

TC: PO 139-151-06
L

JOB LOCATION

① ADDRESS: 14735 (STREET NO) Eagle Brook Dr. (STREET) ② FILE:

③ CITY: ④ TAX PARCEL NO.:

⑤ SUBDIVISION: Clear Creek Estates ⑥ LOT: 28 ⑦ BLOCK: II

OWNER

⑧ NAME: DeLano (FIRST) Roosevelt (MIDDLE) Johnson (LAST)

⑨ MAILING ADDRESS: 101 Shady Oak Tr.

⑩ CITY: Charlotte ⑪ STATE: N.C. ⑫ ZIP: 28210

⑬ PHONE: (WORK) 553-8542 ⑭ (HOME) 553-8542

REQUEST

This request is for a(n):

⑮ ☐ New installation permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ■ Residence ⑳ ■ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type?

㉓ Maximum occupancy? 2 ㉖ Maximum number of employees?

㉔ Basement? ☐ yes ■ no ㉗ Maximum number of seats?



yard slope

㉘ Accurately dimensioned plot

WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☐ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉚ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed:

Date:

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Date Received 12-28-84

MECK C... Y DEPARTMENT OF
RECEIVED
DEC 2 8 1984
ENVIRONMENTAL HEALTH

SIR No. 21740
T.C. No. 139-151-06
Map Date 12/5/83

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Clear Creek Estates Inc
LAST FIRST MIDDLE

2) ADDRESS OF OWNER 1740 E. Independence Blvd. Charlotte, NC ZIP 28205

3) PHONE NO. Home — Office 372-2565

4) LOCATION OF PROPERTY Cobb Rd approx 1/2 mi from NC #24-27
STREET OR COUNTY ROAD

5) SUBDIVISION Clear Creek Estates LOT NO. 28 BLOCK NO. II

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE: DEED BOOK 4738 PAGE NO. 0571

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

Please see attached plat

7) ACCURATELY DIAGRAM & DIMENSION LOT

F. P. Newman
~~OWNER~~ Agent

EHD-5-76

Environmental Health Department's Copy