

9411 BRENDA ANN RD

7/13/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

Mecklenburg County
Health Department

November 29th, 1991

Daniel Hydrick Porter
8620 Wilkinson Boulevard
Charlotte, NC 28214

RE: Property located at 9403 Brenda Ann Road 7
FILE: 7868A
PARCEL: 113-163-05PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 12366) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Per Gene Vaughan

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure (2)

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12366


File: 78 69 A Action 2


Parcel: 10113-16305 ☐ PC

Location: 9403 Brenda Ann Rd
Subdivision: Berryhill Park
Lot: 7 Block: Acres: .34
Owner: Daniel H. Porter
Address: 8620 Wilkinson Blvd.
Charlotte, N.C. 28214

Comments: Would require well

Described by: William A. Marlin
Date: 11-27-91





***** EVALUATION KEY *****
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 6-15%	S PS (U) complex slopes	S PS (U) Depression	S PS U	S PS U	S PS U
Texture	S (PS) U Slightly Expansive clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Subsoil Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	(S) PS U 7+8" To water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	(S) PS U 7+8" @	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	(S) PS U 7+8"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S PS (U) Restricted	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IIe Cecil-Lille	complex slopes	Depression			
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

$50.00 #1347
11/20/91

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 7868A

TC: 113-163-05

☑ PC ☐ REPT

JOB LOCATION

① ADDRESS: 9403 BRENDA ANN RD

② SUBDIVISION: BERRY HILL PARK ③ LOT: 7 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: _____ PAGE NO.: _____ PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: DANIEL (FIRST) HYDRICK (MIDDLE) PORTER (LAST)

⑧ MAILING ADDRESS: 8620 WILKINSON BLVD

⑨ CITY: CHARLOTTE ⑩ STATE: N.C. ⑪ ZIP: 28214

⑫ PHONE: (WORK) 394-6319 (HOME) 394-5066

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Donald H. Porter

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 11-20-91

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

TO: ENVIRONMENTAL HEALTH DEPT.
BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

DATE 11/20/97

FROM: COUNTY ENGINEERING DEPARTMENT

EHD FILE _____ JURISDICTION CODE Mck

PARCEL NUMBER # 113-163-05

ASSIGNED ADDRESS 9403 Brenda Ann Rd

EXISTING ADDRESS _____

PROJECT NAME LA

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	DISAPPROVED
1. SUBDIVISION REGULATIONS	/ /	/ /*
2. FLOODWAY REGULATIONS	/ /	/ /*
3. EROSION CONTROL REGULATIONS	/ /	/ /*
4. PUBLIC UTILITY EASEMENT	/ /	/ /*

	PRESENT	NOT PRESENT
5. PUBLIC UTILITY EASEMENT	/ /*	/ /
6. PROPERTY FRONTS ON THOROUGHFARE	/ /*	/ /
7. DRIVEWAY PERMIT REQUIRED	/ /*	/ /

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: Perk Test

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: _____

OPWEAR 06-88

NEW ADDRESS / /*

FORM 100