Date Received 7-6-83

MECK COUNTY DEPARTMENT OF
RECEIVED
JUL 6 1983
ENVIRONMENTAL HEALTH

SIR No. 19842

T. C. No. 193-211-18

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Ely (LAST) Jimmy (FIRST) Eugene (MIDDLE)

2) ADDRESS OF OWNER 6616 Sardis Rd ZIP 28211

3) PHONE NO Home 364-3530 Office 889 5400

4) LOCATION OF PROPERTY Industrial Dr (STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent disposal.

7) ACCURATELY DIAGRAM & DIMENSION LOT

Jimmy Ely
OWNER

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19842

T.C. NO. 193-211-18

(Ground Absorption Sewage Disposal)

OWNER: Jimmy Ely
ADDRESS: 6610 Sardis Rd 28211
PLAT NO:
LOT SIZE: 1.4 Acres
LOCATION OF SITE: Industrial Drive

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-8	S (PS) U — 2-8	S RS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS U — Clayey	S (PS) U — Clayey	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — Blocky	S (PS) U — Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U — 40-45	S (PS) U — 36-40	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — None	S (PS) U — None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — Adequate	S (PS) U — Adequate	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IIa	IIa		
9. SITE CLASSIFICATION	P, Suitable	P, Suitable		
10. SOIL SERIES	Cecil	Cecil		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Ramsey
Title: Soil Scientist

Date: 7-11-83

EHD 539 (Revised: 6/82)


Cecil
2-3 36-40
Cecil
2-3
40-46
370
Cecil
2-3
181 36-40
Industrial Drive

Serial No. 5104

SIR No. 19842

T. C. No. 193-211-18

Date Issued 7-13-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Ely, (LAST) Jimmy (FIRST) C. (MIDDLE)

ADDRESS OF OWNER 6610 Sardis Rd., Charlotte, NC ZIP 28211

LOCATION OF PROPERTY Industrial Dr. (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. Provisionally Suitable
The permeability rate determined by the investigation was The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling or construction, including the placing of any impervious material on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration and repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

W. B. Ramsey
EHD-S-76 Soil Scientist

Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

Date Received 7-22-83

RECEIVED
JUL 22 1983
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 19842

T. C. No. 193-21-19


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair on individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) Mobile Home ____Yes X No
Residence ____Yes X No

4) No of Bedrooms ____

5) Business Use Max No Employees 5

6. Washing Machine ____Yes X No

7. Garbage Disposal ____Yes X No

8. Dishwasher ____Yes X No

9. Water Supply
A) Individual Well X
B) Governmental System ____
C) Community System
1 Well source ____
2 Governmental source ____

10. Sewage System
House located within 200 feet of public sewer ____Yes X No
House located within 200 feet of community sewer ____Yes X No

11. FHA Case No ____

12 VA Case No. ____

13) NAME OF OWNER Ely (LAST) Jimmy (FIRST) Eugene Jr (MIDDLE)

14) ADDRESS OF OWNER 6610 Sardis Rd

15) PHONE NO. Home 364-3530 Office 889 5400

16) LOCATION OF SYSTEM 1332 Industrial Drive (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES ____ NO DATE RUN 7-13-83

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

7-22-83
DATE OF APPLICATION

Jimmy Ely
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 7-25-83

Serial No. 6618

SIR No. 19842

T. C. No. 193-211-19

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Ely, Jr. (LAST) Jimmy (FIRST) Eugene (MIDDLE)

ADDRESS OF OWNER 6610 Sardis Road, Charlotte, NC ZIP 28211

LOCATION OF LOT 1332 Industrial Drive (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19842. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Ralph Mills
Environmentalist

Dave D. Hamilton Jr.
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy


Date Issued SEPT 22ND 1983 Serial No. 6664 ICAR(S) Permit No. 19842

T. C. No 193-211-18

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19842, dated 7-22-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before OCT 31ST 1983, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS IIA

Liquid Capacity of Tank 1500 gal

Type Construction Pre Cast Concrete

Location and/or Nature of Line

Total Line Length 200 1½ FT.

Number of Lines FOUR

Size 5 FT

Distance from Property Line 10 FT. R&P 100 FT

Distance from Well NOT IN USE

NAME OF OWNER ELV JIMMY

LOCATION OF PROPERTY 1332 INDUSTRIAL DRIVE

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

FOUR TRENCHES TO BE 50FT x 3FT x 12 INCHES STONE - HAY OR STRAW OVER-GRADE BOTH - LIFT STATION

Comments:

Division or Section Head

Ralph Mills
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

BI 10-19-83

C of A (s) No. 19842

Date Issued 10-18-83 Serial 6183 T C. No 93-217 -18

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner ELY, JIMMY (LAST, FIRST, MIDDLE)

Location of Property 1332 INDUSTRIAL DRIVE

Application Number 19842 Permit Number 19842

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material Pre Cast Concrete

Total Length of Drain Tile 200 lin FT Number of Lines EIGHT

Depth of Filter Material 12 inches Cover Depth 1 FT 2 FT

Water Supply Source well Distance from Water Source 80 FT. NE of Door

Excavation Inspected 10-18-83 (DATE) Tank Inspected 10-18-83 (DATE)

Nitrification Field Inspected 10-18-83 (DATE)

Washing Machine Line Inspected If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been X installed or constructed, ——— altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments ———

Ralph Hilles
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL PROTECTION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

RECEIVED JAN 1 3 1994

(OFFICE USE ONLY)
FILE: 19845
TC: 193-211-19 L

① ADDRESS: 1332 (STREET NO) Industrial Dr (STREET) ② FILE:
③ CITY: Matthews NC ④ TAX PARCEL NO.: 193-211-19
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

⑧ NAME: Jimmy (FIRST) EUGENE (MIDDLE) Ely (LAST) JR.
⑨ MAILING ADDRESS: 3724 Aysuugh Rd
⑩ CITY: Charlotte ⑪ STATE: NC ⑫ ZIP: 28211
⑬ PHONE: (WORK) 704 842-7425 ⑭ (HOME) 704 525 6898

This request is for a(n):

⑮ ☐ New installation permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify) Rough in Plumbing For Future Addition OK.

System will serve:

⑲ ☐ Residence ⑳ ☐ Mobile home
㉒ Number of bedrooms? 0
㉓ Maximum occupancy? 10
㉔ Basement? ☐ yes ☒ no

㉑ ☐ Business or place of public assembly
㉕ Type? Existing Warehouse Addition
㉖ Maximum number of employees? 10
㉗ Maximum number of seats? 0

WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉚ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: [signature]
Date: 1-13-94

㉘ Accurately dimensioned plot

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Serial No. 9305

SIR No. 19842

Date Issued 1/31/86

T. C. No. 193-211-19

Map Date L CRJ

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Ely, Jimmy Eugene, Jr.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 3724 Ayslough Rd. ZIP 28211

LOCATION OF LOT 1332 Industrial Dr.
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19842. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

* * * USE EXISTING SYSTEM * * *

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

B. R. Ferguson
Environmentalist

Eric D. Lindler Jr.
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 7-6-23

MECK COUNTY DEPARTMENT OF
RECEIVED
JUL 6 1923
ENVIRONMENTAL HEALTH

SIR No. 19842

T. C. No. 193-211-18

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Ely (LAST) Jimmy (FIRST) Eugene (MIDDLE)

2) ADDRESS OF OWNER 9610 Sardis Rd ZIP 28211

3) PHONE NO Home 364-3530 Office 889 5400

4) LOCATION OF PROPERTY Industrial Dr (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge

7) ACCURATELY DIAGRAM & DIMENSION LOT

Jimmy Ely
OWNER

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19842

T.C. NO. 193-211-18

(Ground Absorption Sewage Disposal)

OWNER: Jimmy Ely
ADDRESS: 6610 Sardis Rd 28211
PLAT NO:
LOT SIZE: 1.4 Acres
LOCATION OF SITE: Industrial Drive

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-8	S (PS) U — 2-8	S RS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS U — Clayey	S (PS) U — Clayey	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — Blocky	S (PS) U — Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U — 40-48	S (PS) U — 36-40	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — None	S (PS) U — None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — Adequate	S (PS) U — Adequate	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IIIa	IIIa		
9. SITE CLASSIFICATION	P. Suitable	P. Suitable		
10. SOIL SERIES	Cecil	Cecil		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Ramsey
Title: Soil Scientist

Date: 7-11-83

EHD 539 (Revised: 6/82)


Cecil
2-3 36-40
Cecil
2-3
40-46
370
Cecil
2-3
181 36-40
Industrial Drive

Serial No. 5104

SIR No. 19842

T. C. No. 193-211-18

Date Issued 7-13-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Ely, (LAST) Jimmy (FIRST) E. (MIDDLE)

ADDRESS OF OWNER 6610 Sardis Rd., Charlotte, NC ZIP 28211

LOCATION OF PROPERTY Industrial Dr. (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and onsite investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plat. Provisionally Suitable
The permeability rate determined by the investigation was The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install a privy, chemical toilet or approved septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of the building or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which may be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above and on the size and type of building constructed thereon.
3. This approval is valid only for the system location staked in the immediate area indicated as acceptable for system installation on the above plat.
4. This approval is void if any grading, filling or other activities occur which change the soil characteristics determined in the area in which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation or construction of a system or the repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

W. B. Ramsey
EHD-S-76 Soil Scientist

Environmental Health Director or Authorized Section Head

Date Received 7-22-83

RECEIVED
JUL 22 1983
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 19842

T. C. No. 193-211-19


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.


Rd
Rd
Rd

Date Issued 7-25-83

Serial No. 6618

SIR No. 19842

T. C. No. 193-211-19

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Ely, Jr. (LAST) Jimmy (FIRST) Eugene (MIDDLE)

ADDRESS OF OWNER 6610 Sardis Road, Charlotte, NC ZIP 28211

LOCATION OF LOT 1332 Industrial Drive (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19842. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Ralph Mills
Environmentalist

David D. Huckabee Jr.
Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department's Copy

Date Issued SEPT 22ND 1983 Serial No. 6664


ICAR(S) Permit No. 19842

T C No 193-211-18

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19842, dated 7-22-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before OCT 31ST, after which date this permit shall be null and void 1983.



PLOT OF SYSTEM

Feasibility Rate PS EVA

Tank Capacity 1500 gal

Type Construction Pre Cast Concrete

Absorption and/or Nitrification Line

Trench length 200 LIN FT

Number of Lines FOUR

Width BDG 5 FT

Depth from soil line 10 FT.
REP 100 FT

Distance from Well NOT IN USE

NAME OF OWNER ELY JIMMY

LOCATION OF PROPERTY 1332 INDUSTRIAL DRIVE

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

FOUR TRENCHES TO BE 50FT X 3FT X 12 INCHES STONE - buy over stone over-grade bids - LIFT STATION

Comments:

Division or Section Head

Ralph Mills
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

BJ 10-19-83

C of A (s) No. 19842

Date Issued 10-18-83 Serial 6183 T C No 93-211-18

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner ELY, JIMMY (LAST, FIRST, MIDDLE)

Location of Property 1332 INDUSTRIAL DRIVE

Application Number 19842 Permit Number 19842

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material Pre Cast Concrete

Total Length of Drain Tile 200 LIN FT Number of Lines EIGHT

Depth of Filter Material 12 inches Cover Depth 1 FT 2 FT

Water Supply Source well Distance from Water Source 80 FT. NW Side

Excavation Inspected 10-18-83 (DATE) Tank Inspected 10-19-83 (DATE)

Nitrification Field Inspected 10-18-83 (DATE)

Washing Machine Line Inspected If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been X installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Ralph Hobbs
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

RECEIVED
JAN 2 1, 19[illegible]
MECKLENBURG COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

(OFFICE USE ONLY)
FILE: 1984[illegible]
TC: 193-[illegible]-19
L

JOB LOCATION

① ADDRESS: 1332 (STREET NO) Industrial Dr (STREET) ② FILE:
③ CITY: Matthews NC ④ TAX PARCEL NO.: 193-211-19
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: Jimmy (FIRST) EUGENE (MIDDLE) Ely (LAST) JR.
⑨ MAILING ADDRESS: 3724 Ayscough Rd
⑩ CITY: Charlotte ⑪ STATE: NC ⑫ ZIP: 28211
⑬ PHONE: (WORK) 704 847-7475 ⑭ (HOME) 704 525 6898

REQUEST

This request is for a(n):

⑮ ☐ New installation permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify) Rough in Plumbing for Future Additional BR

DESIGN CRITERIA

System will serve:

⑲ ☐ Residence ⑳ ☐ Mobile home
㉒ Number of bedrooms? 0
㉓ Maximum occupancy? 10
㉔ Basement? ☐ yes ☒ no

㉑ ☐ Business or place of public assembly
㉕ Type? Existing Warehouse Addition
㉖ Maximum number of employees? 10
㉗ Maximum number of seats? 0

WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉚ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledge that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: [signature]
Date: 10-13-92

㉘ Accurately dimensioned plot

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Serial No. 9305

Date Issued 1/31/86

SIR No. 19842

T. C. No. 193-211-19

Map Date L CKT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Ely, Jimmy Eugene, Jr.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 3724 Ayslough Rd. ZIP 28211

LOCATION OF LOT 1332 Industrial Dr.
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO._____ BLOCK NO._____

MAP BOOK NO._____ PAGE NO._____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19842. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.

2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

* * * USE EXISTING SYSTEM * * *

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

B. R. Ferguson
Environmentalist

Eric D. Lubin Jr.
Environmental Health Director, or Authorized Section Head

EHB-5-76

Environmental Health Department's Copy