Date Received 6/29/11

APT No. 12777
P.O.
T. C. No. 227-121-05

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Wilson, Henry G.
LAST FIRST MIDDLE

2) ADDRESS OF OWNER P.O. Box 612, Charlotte, ZIP 28201

3) PHONE NO Home 332-2072 Office 334-9765


4) LOCATION OF PROPERTY Mountain Ridge Road
STREET OR COUNTY ROAD

5) SUBDIVISION Pine Plantation LOT NO 2 BLOCK NO 1

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK 3948 PAGE NO 0649

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Henry G. Wilson
OWNER

EHD-5-76

Environmental Health Department's Copy

SOIL INVESTIGATION REPORT

Date of Investigation June 29, 1977 APT NO. 12777

Owner H. G Newson

Location of Property High Ridge Rd. Ext. lot No 2 Block 1

Soil Suitability Ratings Taxlede No. 80 227 -121-5

Soil Properties	Soil 1	Soil 2	Soil 3	Soil 4
1. Soil Series	Ceci			
2. Soil Slope	suitable 2-6%			
3. Soil Depth	suitable >48"			
4. Soil Texture	provisionally suitable clay			
5. Soil Structure	provisionally suitable blocky			
6. Restrictive Horizons	—			
7. Soil Drainage	suitable water table 36"			
8. Soil Permeability (Percolation Rate)	provisionally suitable moderate 60 min/in			
9. Other	—			
10. Overall Rating	provisionally suitable			


Recommendations Based on this investigation the lot was found to have an acceptable area of provisionally suitable soils for installation of a septic tank system. System design should be based on a percolation rate of 60 min/in

See diagram on back

W. Edmund Casavant
Soil Scientist

3/16/75
END 539

DIAGRAM OF PROPERTY



3/18/75
EHD 539

Serial No. 1037

PTR No. 12777

Date Issued June 30, 1977

T C No P.O.227-121-05

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Newson (LAST) Henry (FIRST) G. (MIDDLE)

ADDRESS OF OWNER P.O. Box 6113, Charlotte, NC ZIP 28207

LOCATION OF PROPERTY High Ridge Road Ext. (STREET OR COUNTY ROAD)

SUBDIVISION Providence Plantation LOT NO 2 BLOCK NO 1



PLOT PLAN

This lot was investigated by an authorized representative of the Mecklenburg County Department of Environmental Health in the manner described above. The soil investigation was conducted on the part of the lot indicated on the above plot. **Provisionally Suitable**

The permeability rate determined by this investigation was **60 min/in.** The said lot is approved for the installation of one individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A complete application must be made requesting the septic system permit for the Mecklenburg County Department of Environmental Health prior to the commencement of construction of the wastewater treatment system.
2. The [illegible] must be determined by the Mecklenburg County Department of Environmental Health at the time of the installation of the system to be at a rate at or faster than the rate obtained above, and on the area designated on the above plot.
3. A [illegible] system must be established in the immediate area indicated as acceptable for system installation on the above plot.
4. The approval is void if any changes in the lot which would affect the findings of the investigation performed on the lot which is the subject of this report are made after construction. Interest in and ownership of the lot does not void this approval.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

W. Edward Caswell
Soil Scientist

John M. Klesson
Environmental Health Director or Authorized Section Head

EHD-S 76

Environmental Health Department's Copy