Date Received 2/15/79

1

APT No. 15100

T. C. No. 051-121-08

Map Date 3/22/79

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER The Southland Corporation
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER P. O. Box 49023, Atlanta, Georgia ZIP 30359

3) PHONE NO. Home _____ Office (404) 321-4528 or 568-7510

4) LOCATION OF PROPERTY 9740 University City Blvd.
(STREET OR COUNTY ROAD)


5) SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK 3200 PAGE NO 141

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.

BOUNDARY SURVEY ATTACHED



7) ACCURATELY DIAGRAM & DIMENSION LOT

Earl Pritchett
OWNER

EARL PRITCHETT

EHD-5-76

Environmental Health Department's Copy

Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 15100
051-121-08

(Ground Absorption Sewage Disposal)

OWNER: The Southland Corporation DATE REQUESTED: 2-15-79
ADDRESS: P.O. Box 49023 PLAT NO.:
COUNTY: ATLANTA, Georgia 30359 LOT SIZE:
LOCATION OF SITE: 9740 University City Blvd (499 Mallard Creek Rd)

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS U	S (PS) 2-10 U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS U	S PS (U) Clay 2-1	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S PS U	S Fill 2 Fa PS (U) Messey	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS U	S PS (U) <48"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS U	S PS (U) Clay layers	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS U	S PS (U) Very Poor	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS U	S PS (U) Very slow	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION		Unsuitable		
SOIL SERIES		Fill over Helena		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)


Recommendations/Comments:

Described By: W.B. Ramsey

Title: Soil Scientist Date: 3-6-79

dhs form 2601 (1/79)
Sanitation

3


Asphalt
Concrete
Sewage Vent
Swamp Standing water
Transformer
Fill over 30
Helena
Bank
Swamp
Standing water

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

March 8, 1979

The Southland Corporation
PO Box 49023
Atlanta, Georgia
30359

RE: 9740 University City Blvd.

Gentlemen:

Reference is made to your "Application for Soil Investigation", recieved on February 15, 1979.

An on-site evaluation was conducted on March 6, 1979, and the site was found to be unsuitable under the provisions of Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a copy of which is enclosed along with Site Evaluation report.

Sincerely,

John R. Adkisson
Environmentalist
On Premises Waste Disposal Section

JRA:ssr

enclosures (2)