NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

PDT 13105
TC 143-341-18
Lot 18 Block E

OWNER: [illegible] Co.
ADDRESS: PO Box 1374
COUNTY: Matthews, N.C.
LOCATION OF SITE: [illegible] Road & Plantywood

DATE REQUESTED: 3-8
PLAT NO.:
LOT SIZE:

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S 2-10% PS 20 30% U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS [illegible] U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Zero to PS ground water U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S moderate PS U	S PS U	S PS U	S PS U
8. OTHER (Specify)	S * PS See note U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Provisionally suitable			
SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: * Lot has steep slopes on approximately 90% of the area. This would probably cause difficulty in the installation of a septic tank system. Plans for the septic tank system layout must be reviewed and approved by O.P.W.S. section Env. Health Dept. before issuance of building permit

Described By: William R. Mallin

Title: Soil Scientist

Date: 3-10-78

DHS Form 2601 (2/77)
Sanitation


120
120
14'
110'

Serial No. 1658

PTR No. 13705

T. C. No. 193-341-18

Date Issued 3/13/78

Map Date -

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Ed Griffin Company
LAST FIRST MIDDLE

ADDRESS OF OWNER P. O. Box 1374, Matthews, N. C. ZIP

LOCATION OF PROPERTY Corner: Idlewild Road & Plentywood Drive
STREET OR COUNTY ROAD

SUBDIVISION Suburban Woods LOT NO 18 BLOCK NO. E



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. Provisionally Suitable

The permeability rate determined by the investigation was [illegible]. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit [illegible] the Mecklenburg County Department of Environmental Health [illegible] the wastewater treatment system [illegible]
2. The size of the septic tank wastewater treatment system which must be [illegible] be determined by the Mecklenburg County Department of Environmental Health [illegible] obtained above and on the size and type of building constructed thereon.
3. This approval [illegible] the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. [illegible] performed on the lot which [illegible] the Mecklenburg County Department of Environmental Health [illegible] the area indicated as acceptable for system installation unsuitable for installation, construction, [illegible] such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William A. Marlin
Soil Scientist

EHD-5-76

John R. Atkinson
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy