Date Received 7/12/77

APT No. 12940

T. C. No. 141 055 45

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Kahala Corp.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER P.O. Box 17576, Charlotte, N.C. ZIP 28211

3) PHONE NO Home _____ Office 366-2585


4) LOCATION OF PROPERTY Timberley Place
(STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 9 BLOCK NO. _____

MAP BOOK NO 10 PAGE NO. 37

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

H. W. Martin, Secy.
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

APT 178HC
TC 141-0554-5
Lot #9

(Ground Absorption Sewage Disposal)

OWNER: Nahala Corp.
ADDRESS: P.O. Box 12576
COUNTY: Charlotte N.C. 28211
LOCATION OF SITE: Tuckaseegee Blvd

DATE REQUESTED: 7-12-77
PLAT NO.:
LOT SIZE: 3 1/16 ac

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 6-15% U	S PS — U	S PS U	S PS U +
2. SOIL TEXTURE (12-24 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S (PS) clay U	S PS — U	S PS U	S PS U
3. SOIL STRUCTURE (12-24 in.) (Clayey Soils)	S PS Moderate U	S PS — U	S PS U	S PS U
4. SOIL DEPTH (In.)	S Superficial PS @ 24" (U) Massive	S PS — U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS U	S PS — U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) Perched PS water U Table	S Perched PS high water (U) Table	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S slow PS 71 min/in (U)	S Subject PS To Flooding (U)	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuit. table	unsuit. table		
SOIL SERIES	Pacolet w. Iredell	Chewacla		

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: Lots in this investigation, the soils are not considered to be consistently suitable for installation of a septic tank system

Described By: William F. Mullen

Title: Soil Scientist Date: 7-26-77

DHS Form 2601 (2/77)
Sanitation


200'

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SIR. NO. 12840
T.C. NO. 141-055-45
MAP DATE
DATE 7-27-77

NAME OF OWNER Kahala Corporation

ADDRESS OF OWNER P.O. Box 17576, Charlotte, NC 28211

LOCATION OF LOT Timberley Place, Lot 9

As determined under the Rules and Regulations of the North Carolina Department of Human Resources, Division of Health Services, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Depth Unsuitable.

Soil Permeability Unsuitable.

John R. Adkisson

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section

JRA:glr

EHD 398
7/77

R