Date Received 8-10-83

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 10 1983
ENVIRONMENTAL HEALTH

SIR No. 19936
T. C. No. PO 055-201-04
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

#2

1) NAME OF OWNER TURNER (LAST) MANNING (FIRST) LEE (MIDDLE)

2) ADDRESS OF OWNER Rt. 2 Box 219 A-9, GASTONIA, N.C. ZIP 28052

3) PHONE NO. Home (704) 827-1247 Office


4) LOCATION OF PROPERTY 2631 MOORES CHAPEL ROAD (STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO. 04+21 BLOCK NO. 201

MAP BOOK NO. 55 PAGE NO. 20 #2

6) DEED REFERENCE: DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 5167

SIR No. 19936

T. C. No. PO 055-201-04

Date Issued 8-18-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Turner, (LAST) Manning (FIRST) Lee (MIDDLE)

ADDRESS OF OWNER Rt. 2, Box 219 A-9, Gastonia, NC ZIP 28052

LOCATION OF PROPERTY 2631 Moores Chapel Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot **Provisionally Suitable**

The permeability rate determined by the investigation was _____ The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling or construction (including the cutting of trees) is performed on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation. Construction, alteration and repair of the system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William B. Martin
Soil Scientist

Billie D. Hamilton
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19936

T.C. NO. PO 055-20104

(Ground Absorption Sewage Disposal)

OWNER: Manning J. Turner
ADDRESS: R.2, Box 219 A-9 Fairview N.C.
PLAT NO:
LOT SIZE: 22,500
LOCATION OF SITE: Off Rocky Chapel Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-6%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U Clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U 36-40"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U >36"	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U >36" to ground water	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	1UA			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cecil-Like			


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William A. Marlin
Title: Soil Scientist
Date: 8-17-83

EHD 539 (Revised: 6/82)


Moore's Chapel Rd
pipeline
Proposed House site
150
150
150
150
Creek Line
Dirt Rd