Date Received 11-7-83

MECK[illegible]Y DEPARTMENT OF
RE[illegible]EIVED
NOV 7 1983
ENVIRONMENTAL HEALTH

SIR No. 20251

T. C. No. 053-092-19

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER PORTE (LAST) RICHARD (FIRST) E. (MIDDLE)

2) ADDRESS OF OWNER RT 5 Box 1019-M ZIP 28105

3) PHONE NO. Home 399-6550 Office 399-4541 (ext 4115)


4) LOCATION OF PROPERTY HAMPTON RD. (STREET OR COUNTY ROAD) Clarks Chapel Rd

5) SUBDIVISION _____ LOT NO. 16 BLOCK NO. _____

MAP BOOK NO. 053-092-19 PAGE NO. _____

6) DEED REFERENCE: DEED BOOK 4485 PAGE NO. 531

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Ex.

_____
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20251
T.C. NO. PO 053-092-19
DATE: November 30, 1983

Richard E. Rorie
Rt. 5, Box 1019-M
Charlotte, NC 28208

Re: Property located at Hawfield Road, Plat #16

Dear Mr. Rorie:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20251

T.C. NO. 90 058-092-19

(Ground Absorption Sewage Disposal)

OWNER: Richard E. Rocco
ADDRESS: Rt 5 Box 1019-M3 Charlotte, N.C. 28215

PLAT NO: #16
LOT SIZE: 18.46

LOCATION OF SITE: Brookshire Blvd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-8%	(S) PS U 2-8%	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U Clay	S (PS) U Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U 36-40"	S PS (U) 30-36"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U Saprolite 36"+	S PS (U) < 36"	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U > 36"	S (PS) U > 36" to ground water	S PS U	S PS U
7. OTHER (Specify)	S PS U Limited Area	S PS U	S PS U	S PS U
8. SOIL GROUP	IV A	IV A		
9. SITE CLASSIFICATION	Provisionally Suitable	Unsuitable		
10. SOIL SERIES	Cecil-Like	Porter-Like		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Recommend plans for system & if not use location be submitted

Described by: William A. Martin
Title: Soil Scientist

Date: 11/25/83

EHD 539 (Revised: 6/82)


60'
Newfield Rd
Parcel Lines
Approx 15'
300'
300'
Parcel Lines
60'