SEE INSTRUCTIONS ON BACK

Date Received 8-28-82

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
AUG 27 1982

Application No. 18959

T. C. No. 057-181-13


Map Date

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**Application for an**
**Installation, Construction, Alteration, and/or Repair Permit**
**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ____ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____ Yes ____ No
Residence ✓ Yes ____ No

4) No. of Bedrooms 3
5) Business Use — Max No Employees ____
6) Washing Machine ✓ Yes ____ No
7) Garbage Disposal ____ Yes ✓ No
8) Dishwasher ✓ Yes ____ No
9) Water Supply:
A) Individual Well ____
B) Governmental System City
C) Community System:
1. Well source ____
2 Governmental source ____
10) Sewage System.
House located within 200 feet of public sewer ____ Yes ✓ No
House located within 200 feet of community sewer ____ Yes ✓ No
11) FHA Case No ____
12) VA Case No. ____

13) NAME OF OWNER Carter (LAST) William (FIRST) E. (MIDDLE)

14) ADDRESS OF OWNER 6624 Pawnee Dr Charlotte, N.C. 28214

15) PHONE NO. Home 392-1695 Office 596-8014

16) LOCATION OF SYSTEM 6624 Pawnee Dr (STREET OR COUNTY ROAD)

17) SUBDIVISION Winterfield Village Lot No. ____ Block No. ____

Map Book No. ____ Page No. ____

18) DEED REFERENCE — DEED BOOK ____ AT PAGE ____

19) HAS A SOIL INVESTIGATION BEEN RUN? ____ YES ✓ NO DATE RUN ____

20) PTR NUMBER (See Instructions) ____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

Aug. 24, 1982
DATE OF APPLICATION

Mrs. W. E. Carter
OWNER

EHD-5-76

Date Issued 8-30-82

Serial No. 5693


ICAR(S) Permit No. 18959

T. C. No. 059-181-13

Map Date _____

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
### (Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18959, dated 8-26-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 9-3-82, after which date this permit shall be null and void.




Pawnee Drive

PLOT OF SYSTEM

Permeability Rate _____

Liquid Capacity of Tank _____

Tank Construction REPAIR

Absorption and / Nitrification Line

Total Line Length 300'

Number of Lines 3

Distance from House >10'

Distance from Property Line >10'

Distance from Well _____

NAME OF OWNER Carter, W. E.

LOCATION OF PROPERTY 6624 Pawnee Drive

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: overflow from both the washing machine and septic tank drainfield into a repair 9' wide * 33' long * 51" of stone keep >20' from the existing drainfields

Division or Section Head

Mike Sexton
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

use the excess soil to fill in low areas over the tank + drainfields and grade to drain all surface water ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 18959

Date Issued 9-9-82 **Serial** 5344 T. C. No. 059-181-13

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

## CERTIFICATE OF APPROVAL

**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

Name of Owner Carter (LAST), W. (FIRST) E. (MIDDLE)

Location of Property 6624 Pawnee Drive

Application Number 18959 Permit Number 18959

**Inspection Data:**

Liquid Capacity of Tank existing Tank Material —

Total Length of Drain Tile 300' Number of Lines 3

Depth of Filter Material 34" Cover Depth 1' to 2'

Water Supply Source city Distance from Water Source >10'

Excavation Inspected — (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 9-9-82 (DATE)

Washing Machine Line Inspected, If Applicable connected to s.t. repair (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ~~installed~~ or constructed, ~~altered~~ or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: use excess soil to build up over the overflow from the septic tank system to the repair. Grade to drain all surface water.

Mike Sexton
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY