

6141 STATESVILLE RD

04121342

6/1/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5572A DATE: 1/31/90

TC: 041-211-22 ☒ CRT

SERIAL № 13075

Name of Owner Jimmy P. McWhirter Juris.:

Address of Property 6141 Statesville Rd

Inspection Data:

Tank Material PCC

Total Length of Drainfield 1350

Number of Lines 10 @ 135

Cover Depth 10"

Water Supply Source CMUD

Distance to Water Source 750

Excavation Inspected 1/31/90

Tank(s) Inspected 1/24/90

Wash Line Inspected NA

High Water Alarm Inspected 1/24/90

system installed in accordance with approved plan, 728w 1/31/90

PLOT

Design: 1990 1500 ST, 1500 DT, PI, CON, 4050 SFT, 12"G cecil CTR# 16
washer box, flow divider

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for 140 child day care

Philo S. Walker R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5572A DATE: 1/22/90

TC: 041-211-22 PL

SERIAL Nº 14501

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated May 10, 1989. All work shall be completed on or before 2/22/90, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



Statesville Ave

PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank 1500 gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3' feet

Total Line Length 1350 feet

Number of Lines 10

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well 7100 feet

NAME OF OWNER Jimmy P. McWhirter

LOCATION OF PROPERTY 6141 Statesville Rd

Comments: 10 Trenches x 135' long x 3' x 12" stone washer box, Flow divider

Division or Section Head

Philo S. Walker R.S.
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

DUKE POWER COMPANY

Form 00184 (6-81)

Dev./Station _____ Unit _____ File No. _____

Subject 1/4 INCH to 15 feet

By _____ Date _____

Sheet No. ___ of ___ Problem No. _____ Checked By RA Date _____

6141 STATESVILLE Rd

STATESVILLE Rd 200' R/W

Property Line

Bldg 70'x70'

341'

501'

1051'

DISTR BOX

80'

DRYING Field

10 Wash 15

Drive Way

Duke Power Co

6141 Statesville Rd

Phone

Business

Residence

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

May 23rd, 1989

Jimmy McWhirter
4020 Wilson Lane
Charlotte, NC 28206

RE: Property located at 6141 Statesville Rd. 22
FILE: 5572A
PARCEL: 04102122

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 12088) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Very truly yours,

Jim Ericson, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12088

File: 5572A Action 1

Parcel: PO 041-211-22 ☐ PC

Location: Statesville Road


Subdivision:

Lot: Block: Acres: 1A+

Owner: Jimmy McWhirter
Address: 4020 Wilson Lane
Charlotte, N. C. 28206

Comments: This Application Appear To overlap previous Tested Area, Marked off Area Tested

Described by: W. B. Ramsey
Date: 5-12-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-4	S (PS) U 2-6	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS (U) H2O 10-16"	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 40-42	S PS (U) 25-36	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Available Space limited	S (PS) U *	S (PS) U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IIa Cecil	IIb Helena				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

May 10th, 1989

Jimmy McWhirter
4020 Wilson Lane
Charlotte, NC 28206

RE: Property located at Statesville Rd. 22
FILE: 5572A
PARCEL: 04102122

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 12082) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

APPLICATION FOR AN IMPROVEMENT PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 5572A
TC: _____
SERIAL: No 18402 ☒ L ☐ CRT

JOB LOCATION

① ADDRESS: 6141 (STREET NO.) Statesville (STREET) Road ② FILE: _____
③ JURISDICTION: Long Creek ④ TAX PARCEL NO.: 041-211-22
⑤ SUBDIVISION: _____ ⑥ LOT: 22 ⑦ BLOCK: 211

OWNER

⑧ NAME: Timmy (FIRST) P. (MIDDLE) McWhirter (LAST)
⑨ MAILING ADDRESS: 4020 Wilson Lane
⑩ CITY: Charlotte ⑪ STATE: NC ⑫ ZIP: 28206
⑬ PHONE: (WORK) 596-2006 ⑭ (HOME) SAME

REQUEST

This request is for a(n):

⑮ ☒ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☐ Residence ⑳ ☐ Mobile home
㉑ ☒ Business or place of public assembly
㉒ Number of bedrooms? _____
㉕ Type? Day Care
㉓ Maximum occupancy? _____
㉖ Maximum number of employees? 12 Employees - 8
㉔ Basement? ☐ yes ☐ no
㉗ Maximum number of seats? TOTAL 120

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☐ Individual well
B ☒ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Timmy P McWhirter
Date: May 10 1989

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 36 months from the date of issuance.

_____ / _____
Environmentalist Date

_____ / _____
Director or Authorized Section Head Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 5/10/89

Name/Company Senita Day Care

Sanitation _____

Vector Control _____

O.P.W.D. /

Service: Inst/Insp
#5572A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

MAY 10 1989

Fee: $ 150 —

C.K. # 1515
in 150.00

Completed by

Collected by

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12082

File: 5572A Action 1

Parcel: ☐ PC

Location: Statesville Rd.

Subdivision:


Lot: 22 Block: Acres: 1.9A

Owner: Jimmy McWhirter
Address: 4020 Wilson Lane
Charlotte, NC 28206

Comments: Previous soil Test Were Made IN Part on Property Next Door.

Described by: W. B. Ramsey

Date: 5-9-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-H	S (PS) U 2-Ce	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 40-48	S PS (U) 20-25	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Other (specify) Appear To Be Adequate For House	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVe Cecil	IVe Helena				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

30 W/

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5572A

TC: 04/24/22

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: STATesville Rd

② SUBDIVISION: _____ ③ LOT: 22 ④ BLOCK: 211

⑤ PARCEL REFERENCE: BOOK NO.: 041 PAGE NO.: 211 PARCEL NO.: 22

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: JIMMY (FIRST) PARKS (MIDDLE) MULBIRTER (LAST)

⑧ MAILING ADDRESS: 4020 WILSON LANE

⑨ CITY: Charlotte ⑩ STATE: N C ⑪ ZIP: 28206

⑫ PHONE: (WORK) 596 2006 (HOME) SAME

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Jimmy P Mulbirter

Date: May 4, 1989

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 5/4/89

Name/Company Delta Day Care

Sanitation ____

Vector Control ____

O.P.W.D. ✓

Service: Soil test
5721A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
MAY 4 1989

Cash 1502
#30.00

Fee: $ 30.00

K Davis
Completed by

Collected by

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12075

File: 5572A

Action _____

Parcel:

☐ PC

Location:


Subdivision:

Lot: Block: Acres: 1.5A

Owner:
Address:

Comments: Survey of Front of Lot 4 — 28 — 89

Described by: W. B. Ramsey
Date: 4/28/89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2–4	S (PS) U 2–6	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS (U) 14" Mottles	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36–48	S PS (U) 20–36	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U Big System For Dry Cut *	S (PS) U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVa Cecil	IVa Helena				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

April 12th, 1989

Jimmy McWhirter
4020 Wilson Lane
Charlotte, NC 28206

RE: Property located at Statesville Rd. 22
FILE: 5572A
PARCEL: 04102122

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 12040) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12040

File: 5572A Action 1

Parcel: ☐ PC

Location: Statesville Rd.

Subdivision:


Lot: 22 Block: 211 Acres: .47

Owner: Jimmy McWhirter
Address: 4020 Wilson Lane
Charlotte, NC 28206

Comments: 16,500 S.F. IN Area I, But A 120 Child Day Care is Planned. The Area For Drain Fields Will Be Tight.

Described by: W. B. Ramsey

Date: 4-11-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-4	S (PS) U 2-6	S PS U Set Aside For Building Parking	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS (U)		S PS U	S PS U	S PS U
Structure	S (PS) U	S PS (U)		S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS (U)		S PS U	S PS U	S PS U
Depth	S (PS) U 36-48	S PS (U) 20-36		S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U		S PS U	S PS U	S PS U
Available Space Limited Area *	S (PS) U	S (PS) U		S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U		S PS U	S PS U	S PS U
Soil Group/Series	IIa Cecil	IIb Helena				
Area Classification	S (PS) U	S PS (U)		S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5572A

TC: 041-021-22

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: Statesville Road

② SUBDIVISION: _____ ③ LOT: 22 ④ BLOCK: 211

⑤ PARCEL REFERENCE: BOOK NO.: 041 PAGE NO.: 21 [illegible] PARCEL NO.: 22

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Timmy (FIRST) Parks (MIDDLE) W Whitter (LAST)

⑧ MAILING ADDRESS: 4020 Wilson Lane

⑨ CITY: Charlotte ⑩ STATE: N C ⑪ ZIP: 28206

⑫ PHONE: (WORK) 596-2006 (HOME) SAME

⑬ Accurately diagram and dimension lot.



See Earlier Report 5538A
As Per Phone Conversation of 3-31-89

⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Timmy P Whitter

Date: April 3 1989

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 4/3/89

Name/Company Jimmy McWhirter

Sanitation ____

Vector Control ____

O.P.W.D. ✓

Service: Soil investigation
5572A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

APR 3 1989

Ck # 1433
$30.00

Fee: $ 30.00

K Sulsta

Mecklenburg County
Health Department

Basil G. Deltu, M.D., M.P.H.
Health Director

March 30th, 1989

Jimmy P. McWhirter
4020 Wilson Lane
Charlotte, NC 28206

RE: Property located at Statesville Road
FILE: ~~5538A~~ 5572A
PARCEL: 04121122

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure (2)

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 16043

File: 5572A ~~5538A~~ Action 2

Parcel: 04121122 ☐ PC

Location: Statesville Road

Subdivision:


Lot: Block: Acres: .49

Owner: Jimmy P. McWhirter
Address: 4020 Wilson Lane
Charlotte, NC 28206

Comments: _____

Described by: W. B. Ramsey

Date: 3-30-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-4	S (PS) U 2-4	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS (U) H20 16"	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 40-42	S PS (U) 20-25	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Available Space 20X200 IN Marked Area *	S PS (U)	S (PS) U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVa Cecil	IVb Helena				
Area Classification	S PS (U)	S PS (U)	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5572A ~~5538A~~

PO TC: 041-21122

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: _____

② SUBDIVISION: _____ ③ LOT: _____ ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 041 PAGE NO.: 21 PARCEL NO.: 22

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Tommy (FIRST) Parks (MIDDLE) Mishler (LAST)

⑧ MAILING ADDRESS: 4020 Wilson Lane

⑨ CITY: Charlotte ⑩ STATE: N C ⑪ ZIP: 28206

⑫ PHONE: (WORK) 596 2006 (HOME) Same.

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Tommy Parks Mishler

Date: March 17th 1989

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 3/17/89

Name/Company Lucitas Day Care

Sanitation ____

Vector Control ____

O.I.W.P. ✓

Service: Sewer Test
#55381

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

MAR 17 1989

CK# 1387

Fee: $ 30.00 30.00

Completed by

Collected by

Mr. Jimmy P. McWhirter
4920 Wilson Lane
Charlotte, N. C. 28206

Mr. Gene Vaughn
Enviromental Health Dept.
Charlotte, Mecklenburg Cty.

Dear Mr. Vaughn

Please accept my May 4th application requesting your permitting for a in-ground water sewage disposal permit.

As you are aware, I have done extensive research and evaluation on water usage by three comparable size day care centers as well as our own present day care water use. This information was acquired through the Child Care Resource Service and The Charlotte Mecklenburg Utility Department. Ms. Robin Gaston with the Utility Department ascertained the water use of the centers that were evaluated.

In Talking with the directors working in these centers, we have determined that the Little Learners Day Care's water usage is the most accurate. This center is licensed for 139 students and has been full since their opening. In using your formular for determining the length of drainage line it figures out to be 880 lenial feet. Based on our 140 student application request, our needs would be the same.

In furtherance, to meet specified ordenance requirements we have enough area set aside for any repair that may be required. The landscaping will be done in a manner to compliment and support our sewage system.

I want to assure you and all your management that any problems encountered will be promptly reported.

Yours very truly

Jimmy P. McWhirter