Date Received July 74

Application No. 7464

T. C. No. 023-093

Map Date 14 Dec 73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR WELL WATER SUPPLY PERMIT

NAME OF OWNER _____ (LAST) _____ (FIRST) _____ (MIDDLE)

ADDRESS OF OWNER Route 7 Box 634 ZIP 28213

PHONE NO. Home _____ Office _____

LOCATION OF PROPERTY _____ (STREET OR COUNTY ROAD)


SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

DEED REFERENCE: DEED BOOK _____ PAGE NO. _____

WELL CONTRACTOR _____ LICENSE NO. _____

Application is hereby made to the Mecklenburg County Health Department for a permit to drill a water well on the hereinabove described lot to be used as a source of _____ individual, _____ semi public, or _____ public water supply:



ACCURATELY DIAGRAM & DIMENSION LOT

12 July 74
DATE OF APPLICATION

OWNER

Application approved and permit hereby granted

Permit No: 7464

ENVIRONMENTALIST

FORM NO. E-20-8-1-72

HEALTH DEPARTMENT'S COPY

K

Date Received 2-5-74

MECK COUNTY HEALTH DEPT.
RECEIVED
FEB 6 1974
ENVIRONMENTAL HEALTH DIVISION

APT No 7464

P.O.T C No 023-093-15

Map Date 12-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Davis (LAST) Leslie (FIRST) Hill (MIDDLE)

2) ADDRESS OF OWNER Route 7 Box 634 Charlotte ZIP 28213

3) PHONE NO Home 596-2299 Office


4) LOCATION OF PROPERTY Marengo Circle (MARENGO) (STREET OR COUNTY ROAD)

5) SUBDIVISION Commanche Park LOT NO 62 BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Leslie H Davis
OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 4032

PTR No 7464
P.O.
T C No 023-093-15

Date Issued February 18, 1974

Map Date 12-14-73

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Davis (LAST) Leslie (FIRST) Hill (MIDDLE)

ADDRESS OF OWNER Route 7, Box 634 ZIP 28213

LOCATION OF PROPERTY Marengo Circle (STREET OR COUNTY ROAD)

SUBDIVISION Comanche Park LOT NO 62 BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct after, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

Jerry Burleson

John K. Robinson

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-9-1-72

HEALTH DEPARTMENT'S COPY

K

Date Received 2-5-74

SEE INSTRUCTIONS ON BACK
MECK COUNTY HEALTH DEPARTMENT
RECEIVED
FEB 6 1974
ENVIRONMENTAL HEALTH DIVISION

Application No 964

P.O.T. C No 023-093-05

Map Date 12-14-73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ✓ Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

3

Yes ✓ No

13) NAME OF OWNER Davis (LAST) Leslie (FIRST) Hill (MIDDLE)

14) ADDRESS OF OWNER Route 7 Box 654 Charlotte NC 28213

15) PHONE NO Home 596-2299 Office

16) LOCATION OF SYSTEM Marego Circle (MARENGO) (STREET OR COUNTY ROAD)

17) SUBDIVISION Commanche Park Lot No 62 Block No

Map Book No Page No.

18) DEED REFERENCE — DEED BOOK AT PAGE

19) HAS A PERCOLATION TEST BEEN RUN? YES ✓ NO DATE RUN

20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

1-30-74
DATE OF APPLICATION

Leslie H Davis
OWNER

REV 10 E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 3846

LA No 7464
P.O.
T C No 023-093-15

Date Issued February 18, 1974

IMPROVEMENTS PERMIT

Map Date 12-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Davis (LAST) Leslie (FIRST) Hill (MIDDLE)

ADDRESS OF OWNER Route 7, Box 634 ZIP 28213

LOCATION OF LOT Marengo Circle (STREET OR COUNTY ROAD)

SUBDIVISION Comanche Park LOT NO 62 BLOCK NO.

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/in on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation Construction, Alteration, and/or Repair Permit", number 7464. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Jerry Buncan
Environmentalist

John R. Albisson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued 23 Jan 74 Serial No. 6921 ICAR(S) Permit No 7464

RO T C No 023-093-15

Map Date 12-14-73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ~~Install~~ or Construct, Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7464, dated 2-5-74 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 23 Jan 75 after which date this permit will be null and void



PLOT OF SYSTEM

Percolation Rate ———

Liquid Capacity of Tank 1500 gal

Tank Construction RC

Absorption and/or Nitrification Lines

Total Line Length 600' 5150 sq ft

Number of Lines 6(15'x100'x17") 3(7½'x50'x17")

Distance from Well 10'

Distance from Property Line 10'

Distance from Well 100' ft

NAME OF OWNER Davis, Leslie H

LOCATION OF PROPERTY Moreno Circle

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used

Comments Reserve pit 2½'x7'x4' gittone (W.C. Sherrill)

Division or Section Head

Environmentalist

If this permit is for the installation or construction of a new system it must be signed by the division or a section head of the Environmental Health Division in order to be valid. On the signature of the Environmentalist is all that is necessary where an existing system is being altered or repaired

EH - E-5-9-1-72

Date Issued 2-14-75

Serial No. 8503

C of A 1st No 7464

F T C No 033-093-45

Map Date 12-14-73

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Davis, Leslie H
LAST FIRST MIDDLE

Location of Property Morenge Cir

Application Number 7464 Permit Number 7464

Inspection Date:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 600'@150' Number of Lines 4'(15'x110'x17") 3'(7½'x50'x14")

Depth of Filter Material 17" Cover Depth 15"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 2-14-75 DATE Tank Inspected 2-14-75 DATE

Nitrification Field Inspected 2-14-75 DATE

Washing Machine Line Inspected, If Applicable 2-14-75 DATE

The undersigned has inspected the Individual Septic Tank System with subsurface soil absorption effluent discharge as described above and it has been ~~approved~~ installed or constructed as noted above in accordance with the permit issued and the requirements of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval by the undersigned is not a guarantee that the system will operate properly or relieve any person firm or corporation using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit and in addition to those listed below under comments. This Certificate of Approval shall be void and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Aeration pit 2½' x 7' x 1' (System started by Ford w.o. Sheriff finished by Robert Bass)

* Note: This system could have problems in the future, due to the fact that heavy equipment was used in the bottom & the nitrification bed causing compaction of soil pores.

Environmentalist

FORM NO E-6-9-1-72