Date Received 10-4-79

PO 1626

APT No 025-081-12

I C No 025-081-12

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Cornelius Land & Stock Co. Inc.
LAST FIRST MIDDLE

2) ADDRESS OF OWNER 1109 Texas Ave Marlinton W.Va ZIP 24954

3) PHONE NO Home 304-799-6434 Office


4) LOCATION OF PROPERTY Off Pucketts Rd
STREET OR COUNTY ROAD

5) SUBDIVISION LOT NO BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK 1156 PAGE NO 493

Applicat[illegible] is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of [illegible] investigation and on-site inspection of the lot hereinabove described for the purpose of determining if the [illegible] is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Cornelius Land & Stock Co. Inc.
Willis V. Cornelius, Pres.
OWNER

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 16216

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # PO 025-081-12

(Ground Absorption Sewage Disposal)

OWNER: CORNELIUS Land & Stock CO DATE REQUESTED: 10-4-79
ADDRESS: 1109 TENTH AVE PLAT NO.:
COUNTY: MAYLINTOW, W. VA 24954 LOT SIZE: 46400
LOCATION OF SITE: PUCKETT RD LOT 9

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-10	S (PS) U 2-16	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy clayey, Note 2:1 Clay)	S PS (U) Clayey 2-1	S PS (U) Clayey 2-1	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S ~~PS~~ (U) Blocky To Massive	S PS (U) Massive	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS (U) <48	S PS (U) <48	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS (U) Clay	S PS (U) Clays	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S PS (U) Slow	S PS (U) Slow	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S ~~PS~~ (U) Slow	S PS (U) SLOW	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable	Unsuitable		
SOIL SERIES	VANCE	HELENA		

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments

Described By: W. B. Ramsey

Title: Soil Scientist Date: 12-4-79

DHS Form 2601
Sanitation
EHD 539 (3/79)


115
VANCE
2-10
330
HELENA
2-10
Lot 9
Hillway DRIVE

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 16216
T.C.NO po 025-081-12
MAP DATE
DATE Dec. 5, 1979

NAME OF OWNER Cornelius Land and Stock Company

ADDRESS OF OWNER 1109 Tenth Ave., Maylinton, W. Va.

LOCATION OF LOT Puckett Road, Lot 9

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive

Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A, 1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office

John R. Adkisson

John R. Adkisson, Environmentalist