Date Received 10/12/82

SEE INSTRUCTIONS ON BACK

ICAR (S) Application No. 19041

T. C. No. 109-201-13

Map Date _____


RECEIVED
OCT 15 1982
MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ____ Install or Construct 2) Yes, Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____ Yes ____ No
Residence X Yes ____ No

4) No. of Bedrooms Four
5) Business Use — Max No Employees ____
6) Washing Machine X Yes ____ No
7) Garbage Disposal ____ Yes ____ No
8) Dishwasher X Yes ____ No
9) Water Supply:
A) Individual Well Yes
B) Governmental System ____
C) Community System:
1. Well source ____
2. Governmental source ____
10) Sewage System:
House located within 200 feet of public sewer ____ Yes X No
House located within 200 feet of community sewer ____ Yes X No
11) FHA Case No ____
12) VA Case No. ____

13) NAME OF OWNER Yard (LAST) Ted (FIRST) Harrell (MIDDLE)

14) ADDRESS OF OWNER 5450 Maplewood Lane, Charlotte, N.C. 28212

15) PHONE NO. Home 536-2443 Office 379-6739

16) LOCATION OF SYSTEM 5450 Maplewood Lane (200' of Lawyers Road) (STREET OR COUNTY ROAD)

17) SUBDIVISION Harlwood Lot No. 5450 Block No. 5400

Map Book No. ____ Page No. ____

18) DEED REFERENCE — DEED BOOK ____ AT PAGE ____

19) HAS A SOIL INVESTIGATION BEEN RUN? X YES ____ NO DATE RUN 1965/1966

20) PTR NUMBER (See Instructions) ____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

October 12, 1982
DATE OF APPLICATION

Ted H. Yard
OWNER

END-5-76

Serial No. 5817

ICAR(S) Permit No. 19041


Date Issued Oct 18th 1982

T. C. No. 109-201-13

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19041, dated Oct 12th 1982 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before Oct 31st 1982, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS IWA

Liquid Capacity of Tank —

Tank Construction —

Absorption and/or Nitrification Lines

Total Line Length 100 LIN FT

Number of Lines TWO

Distance from House 10 FT

Distance from Property Line 50 FT

Distance from Well 70 FT

NAME OF OWNER HAND TED

LOCATION OF PROPERTY 5450 MAPLEWOOD LANE

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: W/M LINE two trenches X be 50 FT long 3 FT wide and three feet with 17" stone-grade boards- hay or straw cover.

Ralph Miller
Environmentalist

Division or Section Head

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

RECEIVED
Mecklenburg County
Health Dept.
SEP

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 19041
TC: 109-201-13
SERIAL: № 14590
☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 5450 (STREET NO.) MAPLEWOOD (STREET) LN. ② FILE:
③ JURISDICTION: ④ TAX PARCEL NO.:
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: TED (FIRST) HARRELL (MIDDLE) HEAD (LAST)
⑨ MAILING ADDRESS: 5450 MAPLEWOOD LN.
⑩ CITY: CHARLOTTE ⑪ STATE: NC ⑫ ZIP: 28212
⑬ PHONE: (WORK) 379-6239 ⑭ (HOME) 536-4444

REQUEST

This request is for a(n):

⑮ ☑ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify) Equipment Shelter

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home
㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 4
㉕ Type?
㉓ Maximum occupancy? 3
㉖ Maximum number of employees?
㉔ Basement? ☐ yes ☑ no
㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☑ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Ted Harrell Head
Date: Sept 23/87

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction Alteration and or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance. Use existing system

D. R. Ferguson — Environmentalist — 9-25-87 Date
Director or Authorized Section Head — 9-25-87 Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.

PROPOSED PLOT PLAN


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 19041

TC: 109-201-13

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: Jeff Harrell Hood

Date: Sept. 23, 1987