S. I. R. NO. ~~46101~~ 19613

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # ~~111-061-03~~ 04

(Ground Absorption Sewage Disposal)

OWNER: Deborah J. Swanson
ADDRESS: 213 Baldwin Ave
COUNTY: Charlotte, N.C.
LOCATION OF SITE: Foster Dr.

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 26,900

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-12%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 Clay)	S (PS) U clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) U Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS U 48"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) PS U None	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS U 76" To ground Water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U moderate	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U See Note	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	✓ provisionally Suitable			
SOIL SERIES	Cori			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.


Recommendations/Comments: Surface water diversion probably necessary for drainfield location

Described By: William R. Martin

Title: Soils Scientist Date: 10-30-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

✓


63'
225
136'
Cecil
2-12-76
100
47
Tractor Dr

Serial No. 3173

PTR No. ~~19191~~ 19613

Date Issued November 1, 1979

T. C. No. 111-061-~~03~~ 04

Map Date 1/3/79


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Swanson, Deborah Love
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 212 Baldwin Avenue, Charlotte ZIP 28204

LOCATION OF PROPERTY 8120 Teeter Drive
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable** The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction including the drilling of a well is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William B. Marlin
Soil Scientist

John B. Johnston
Environmental Health Director or
Authorized Section Head

EHD-S-76

Environmental Health Department's Copy

Date Received 4-19-83

SEE INSTRUCTIONS ON BACK

ICAR(S) Application No. 19613

T. C. No. 111-061-03 ?


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) To Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No

4) No. of Bedrooms 3
5) Business Use — Max No. Employees N/A
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ✓ Yes ___ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply
A) Individual Well ✓
B) Governmental System N/A
C) Community System:
1. Well source N/A
2 Governmental source N/A
10) Sewage System.
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No. N/A
12) VA Case No. N/A

13) NAME OF OWNER Swanson (LAST) Deborah (FIRST) Love (MIDDLE)

14) ADDRESS OF OWNER 9110 Teeter Drive Charlotte N.C. 28215

15) PHONE NO. Home 531-7036 Office 568-7214

16) LOCATION OF SYSTEM 9120 Teeter Drive (STREET OR COUNTY ROAD)

17) SUBDIVISION Mallard Township Lot No. 8120 Block No. ___

Map Book No. 111 Page No. 061-03

18) DEED REFERENCE — DEED BOOK 4200 AT PAGE 0412

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) 16191 (Improvement Permit Serial No. 3680 Issued 11-1-79) Issued November 1, 1979 Serial No. 3113

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

April 15, 1983
DATE OF APPLICATION

Deborah Love Swanson
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 4-28-83

Serial No. 6391

SIR No. 19613

T. C. No. 111-061-04

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
IMPROVEMENT PERMIT
TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Swanson, (LAST) Deborah (FIRST) Love (MIDDLE)

ADDRESS OF OWNER 8110 Teeter Dr., Charlotte, NC ZIP 28215

LOCATION OF LOT 8120 Teeter Drive (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO._____ BLOCK NO._____

MAP BOOK NO._____ PAGE NO._____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19613. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 19613

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

T. C. # 111-061-03 04

(Ground Absorption Sewage Disposal)

OWNER: Deborah J. Swanson
ADDRESS: 213 Ballyvin Ave
COUNTY: Iredell, N.C.
LOCATION OF SITE: Teeter Dr.

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 26,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-12%	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 Clay)	S (PS) U clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S (PS) U Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS U 48"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) PS U None	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	(S) PS U 76" to ground water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U moderate	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U See Note	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	✓ Provisionally Suitable			
SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.


Recommendations/Comments: Surface water diversion probably necessary for drainfield location

Described By: William R. Martin

Title: Soils Scientist Date: 10-30-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

✓


63'
225
136'
Creek
2-12-76
100
47

Serial No. 3173

PTR No. ~~16191~~ 19613

Date Issued November 1, 1979

T. C. No. 111-061-03 04

Map Date 1/3/79


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Swanson, Deborah Love
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 212 Baldwin Avenue, Charlotte ZIP 28204

LOCATION OF PROPERTY 8120 Teeter Drive 2200'
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank, wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William A. Marlin
Soil Scientist

John A. Grissom
Environmental Health Director or
Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

MECK. COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

RECEIVED APR 19 1983

Date Received 4-19-83

ICAR(S) Application No. 19613

T. C. No. 111-061-03 ?


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) To Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No

4) No. of Bedrooms 3
5) Business Use — Max No. Employees N/A
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ✓ Yes ___ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply:
A) Individual Well ✓
B) Governmental System N/A
C) Community System:
1. Well source N/A
2. Governmental source N/A
10) Sewage System:
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No. N/A
12) VA Case No. N/A

13) NAME OF OWNER Swanson (LAST) Deborah (FIRST) Love (MIDDLE)

14) ADDRESS OF OWNER 8110 Teeter Drive Charlotte N.C. 28215

15) PHONE NO. Home 531-7036 Office 568-7214

16) LOCATION OF SYSTEM 8110 Teeter Drive (STREET OR COUNTY ROAD)

17) SUBDIVISION Mallard Township Lot No. 8120 Block No. ___

Map Book No. 111 Page No. 061-03

18) DEED REFERENCE — DEED BOOK 4200 AT PAGE 0412

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) 16191 (IMPROVEMENT PERMIT SERIAL NO. 3680 ISSUED 11-1-79) ISSUED NOVEMBER 1, 1979 SERIAL No. 3113

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

April 15, 1983
DATE OF APPLICATION

Deborah Love Swanson
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Bo # 4/28/83

Date Issued 4-28-83

Serial No. 6391

SIR No. 19613

T. C. No. 111-061-04

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
IMPROVEMENT PERMIT

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Swanson, (LAST) Deborah (FIRST) Love (MIDDLE)

ADDRESS OF OWNER 8110 Teeter Dr., Charlotte, NC ZIP 28215

LOCATION OF LOT 8120 Teeter Drive (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19613. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy