Date Issued 5-2-79 **Serial No. 2672** C of A (s) No 5203

P.O. T C No 031-093-06

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION
CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Williams (LAST) Jim (FIRST) H. (MIDDLE)

Location of Property Stoney Ridge Drive

Application Number 5203 Permit Number 5203

Inspection Data:

Liquid Capacity of Tank 1500 gallons Tank Material precast concrete

Total Length of Drain Tile 495' + 125' Number of Lines 5 + 4

Depth of Filter Material 17" stone, 6" sand Cover Depth 30"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected — (DATE) Tank Inspected 5-2-79 (DATE)

Nitrification Field Inspected 5-2-79 (DATE)

Washing Machine Line Inspected, If Applicable 5-2-79 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments agreement form - modified system. poor soil

Michael A. Sexton
Environmentalist

EHD-5-76

Environmental Health Department's Copy