Date Received 3-5-84

RECEIVED

SIR No. 2c747

T.C. No. 099-271-01

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Porterfield, (LAST) John (FIRST) Terrill (MIDDLE)

2) ADDRESS OF OWNER 7729 Hood Road, Charlotte, NC ZIP 28215

3) PHONE NO Home 536-4889 Office _____

4) LOCATION OF PROPERTY ~~5411~~ Hickory Grove Road (STREET OR COUNTY ROAD)

5) SUBDIVISION Clear Run LOT NO 11 BLOCK NO _____

MAP BOOK NO 99 PAGE NO 27

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and on-site inspection of the lot hereinafter described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

See attached preliminary subdivision plat

OWNER

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20747

T.C. NO. PO 099-271-01

(Ground Absorption Sewage Disposal)

OWNER: John T. Porterfield
ADDRESS: 7729 Hood Road
Charlotte, N.C. 28215
LOCATION OF SITE: off Vickery Grove Road

PLAT NO: Lot 11
LOT SIZE: 18,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S 4-15% PS U	S PS 3-8% U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS Clay U	S PS Clay U loam	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS Blocky U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS 36-48" U	S PS 36-40" U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS 7-36 U	S PS 7-36" U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS 7-36" to ground water U	S PS Depression Drainage wet U	S PS U	S PS U
7. OTHER (Specify)	S PS Restricted Area U	S PS U	S PS U	S PS U
8. SOIL GROUP	WA	WA		
9. SITE CLASSIFICATION	unsuitable	unsuitable		
10. SOIL SERIES	Cecil Like	Depression Drainageway		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William R. Martin
Title: Soil Scientist

Date: 3-15-84


Clear Run
Drainageway Depression

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20747
T.C. NO. PO 099-271-01
DATE: 5-17-84

John T. Porterfield
7729 Hood Road
Charlotte, NC 28215

RE: Property located at Hickory Grove Road, Lot 11

Dear Mr. Porterfield:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure