Date Received 7/2/79

MECK COUNTY DEPARTMENT OF
RECEIVED
JUN 26 1979
ENVIRONMENTAL HEALTH


APT No 15873
T. C. No 193-066-09
Map Date 1/14/77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER (LAST) J. W. Huntley Const Co. Inc (FIRST)
2) ADDRESS OF OWNER P. O. Box 35242 Charlotte (ZIP) N.C. (MIDDLE) 28212
3) PHONE NO Home 366446 Office same
4) LOCATION OF PROPERTY Blakeney Dr. off Olde Creek Trail (STREET OR COUNTY ROAD)
5) SUBDIVISION Olde Creek LOT NO Lot 12 BLOCK NO E
MAP BOOK NO 14 PAGE NO 181
6) DEED REFERENCE DEED BOOK 3566 PAGE NO 176

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of soil investigations and percolation tests on the property hereinafter described for the purpose of determining the feasibility of using individual septic tank wastewater treatment system with subsurface soil absorption or effluent disposal.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Wayne Huntley
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

15873
193-066-09

(Ground Absorption Sewage Disposal)

OWNER: F.W. HUNTLEY Const. Co.
ADDRESS: P.O. Box 25242
COUNTY: Meck. 28212
LOCATION OF SITE: Blackvine Drive

DATE REQUESTED: 7-2-79
PLAT NO.:
LOT SIZE: 2a,200

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (Z)	S (PS) 2-10 U	S PS Complex (U)	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2-1 (U)	S PS 2-1 (U)	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS Massive (U)	S PS Massive (U)	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS >48 (U)	S PS >48 (U)	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S PS Clays (U)	S PS Clays (U)	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS Slow (U)	S PS Slow (U)	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS Slow (U)	S PS Slow (U)	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable	Unsuitable		
SOIL SERIES	Fillmore Wilkes & Helena	Helena		

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: W. B. Ramsey
Title: Soil Scientist Date: 7-12-79

DHS Form 2601 (2/77)
Sanitarion

2


Black Vine Dr.
Fill in over
Wilkes
Helm
Helm
2-10
Ditch

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15873
T.C. NO. 193-066-09
MAP DATE 1/14/77
DATE 7/13/79

NAME OF OWNER F. W. Huntley Construction Company, INC.

ADDRESS OF OWNER PO Box 25242 Charlotte, NC 28212

LOCATION OF LOT Blackvine Drive Beside Lot 2 Block E

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive
Soil Permeability Unsuitable

John R. Adkisson, Environmentalist

EHD 398
7/77

R