

11325 BLAIR RD

13715306

6/25/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

APPLICATION FOR AN IMPROVEMENT PERMIT

PD 02-05-91 $125.00 ck #1100

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: ~~7094A~~ 7093A
TC: 137-151-06 ✓
SERIAL: № 21280 ☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 11325-B (STREET NO.) Blair Road (NC51) (STREET) ② FILE: _____
③ JURISDICTION: Davidson ④ TAX PARCEL NO.: 137-151-06
⑤ SUBDIVISION: _____ ⑥ LOT: _____ ⑦ BLOCK: _____

OWNER

⑧ NAME: William (FIRST) C. (MIDDLE) Honline (LAST)
⑨ MAILING ADDRESS: 1100 Blair Road
⑩ CITY: Charlotte ⑪ STATE: N.C. ⑫ ZIP: 28227
⑬ PHONE: (WORK) _____ ⑭ (HOME) 545-6985

REQUEST

This request is for a(n):

⑮ ☐ New permit
⑯ ☒ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☐ Residence ⑳ ☐ Mobile home
㉒ Number of bedrooms? _____
㉓ Maximum occupancy? _____
㉔ Basement? ☐ yes ☐ no
㉑ ☒ Business or place of public assembly
㉕ Type? Packaging & Dressed Poultry
㉖ Maximum number of employees? 2
㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: William C. Honline

Date: Feb. 4- 1995

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 36 60 months from the date of issuance.

Environmentalist / Date

Director or Authorized Section Head / Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date: 2-5-91

Name/Company: Pauline C. Hankins

Sanitation _____

Vector Control _____

O.P.W.D. X

Service: Improvement Permits

SIR 7093 A. Post

7094 A

Duplicate 11325A Paid
11325B Paid
1105

MECK. HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
FEB 5 1991

Fee: $ 250.00 CK# 1100 $250.00

NOTICE:

A processing fee of $15.00 will be charged for all returned checks in accordance with N.C. General Statute 25-3-512.

P. Johnstine
Completed by

Collected by

APPLICATION FOR SOIL INVESTIGATION

1.0

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 7093A

RO TC: 137-151-06

☑ PC ☐ REPT

JOB LOCATION

① ADDRESS: 11325-B Blair Road (NC 51)

② SUBDIVISION: _____ ③ LOT: _____ ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 137 PAGE NO.: 151 PARCEL NO.: 06

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: William (FIRST) C. (MIDDLE) Hanline (LAST)

⑧ MAILING ADDRESS: 11000 Blair Road

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28227

⑫ PHONE: (WORK) _____ (HOME) 545-6985

⑬ Accurately diagram and dimension lot.



*Alteration due to widening of Albemarle Road

Mail Copy of Report to:

NCDOT
Appraisal Section
500 W. Trade Street
Suite 317-B
Charlotte, N.C. 28202

*Note: Soil Test is requested for One-Story Block Business

⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Pauline C. Hanline

Date: 10/16/90

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date: 10-29-90

Name/Company: State of N.C. / Dept. of Transportation

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: Apps. for Soil Investigations (6)
11325-A Blair Rd (NC 51) #7094A
11325-B Blair Rd. (NC 51) #7093A
11220 Albemarle Rd #7096A
11421 Alb. Rd. #5074
12401 Alb. Rd. #5419
1200 Alb. Rd. #5504

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
OCT 29 1990

Fee: $ 300.00

NOTICE: Ck # 101404 $300.00

A processing fee of $15.00 will be charged for all returned checks in accordance with N.C. General Statute 25-3-512.

Completed by

Collected by

Mecklenburg County
Health Department

October 25th, 1990

William C. Hanline
11000 Blair Road
Charlotte, NC 28227

RE: Property located at 11325 -B Blair Road
FILE: 7093A
PARCEL: PO 137-151-06

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as PROVISIONALLY SUITABLE for such an installation. A copy of the Site Evaluation Report (Serial Number 16773) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Very truly yours,

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 16773

File: 7093A Action 1

Parcel: PO 137-151-06 PC

Location: 11325-B Blair Rd

Subdivision:


Lot: Block: Acres: Approx .13 ac.

Owner:
Address:

Comments: Would need lift pump Area #1 Approx 50'x100'

Described by: William R. Marks

Date: 10-25-90



*** EVALUATION KEY ***

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 7-36" To Wet	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U ~~40"~~ 40-43"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 7-40"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U Limited	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil-Lloyd					
Area Classification	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U