R

Date Received 4-5-73

APT No. 5131

T C No _____

Map Date _____

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER HILTON (LAST) CHARLES (FIRST) EDWARD (MIDDLE)

2) ADDRESS OF OWNER 4824 NEVINS RD ZIP _____

3) PHONE NO. Home 596-0515 Office —


4) LOCATION OF PROPERTY CABARRUS RD (STREET OR COUNTY ROAD) 1200' N OF Co. Rd. #3110

5) SUBDIVISION _____ LOT NO 6 BLOCK NO. _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK 2321 PAGE NO 12-85

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



Charles E. Hilton
OWNER

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. ~~4-18-73~~
2. _____
3. _____

SDR No. 5931
T.C. No. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Charles Edward Hilton

ADDRESS OF OWNER 4824 Nevins Road ZIP _____

LOCATION OF LOT Cabarrus Road

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	4-17-73	300 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

R. M. Reynolds
Environmentalist

(Stencil No.)
KMD 398
8/70

FORM NO.
E-19-8-14-70