Date Received 1/23/80

MECKLENBURG COUNTY
RECEIVED
JAN
ENVIRONMENTAL HEALTH

APT No. 16484
T C No 025-106-13
Map Date 8/7/78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Mullins, (LAST) Charles (FIRST) Dean (MIDDLE)

2) ADDRESS OF OWNER P.O Box 628, Huntersville, NC ZIP 28078

3) PHONE NO Home 875-2527 Office (Wk.) 377-4471 (Cathy Mullins)


4) LOCATION OF PROPERTY Huntersville-Mt Holly Rd Off on Vance Rd, Turn N to Forest Acres, Take 1st Dirt (STREET OR COUNTY ROAD) St to Left

5) SUBDIVISION Forest Acres #1 LOT NO 10A BLOCK NO B

MAP BOOK NO 10 PAGE NO 271

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the purpose of investigation and an on site inspection of the property described for the purpose of determining if it is suitable for the installation of a septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Charles Dean Mullins
+ Carolina Development Inc.
OWNER

EHD-5-76

Environmental Health Department's Copy

S. I. R. NO. 16484

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 025-106-13

(Ground Absorption Sewage Disposal)

OWNER: Charles P. Mullis
ADDRESS: PO Box 628
COUNTY: Hunterville, N.C. 28078
LOCATION OF SITE: Woodland Drive in Forest Acres

DATE REQUESTED: 1-23-80
PLAT NO.:
LOT SIZE: 27424

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S / PS 0-2 / U	S / PS 2-10 / U	S / PS / U	S / PS / U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 Clay)	S / PS Clayey 2:1 / U	S / PS Clayey 2:1 / U	S / PS / U	S / PS / U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S / PS Massive / U	S / PS Massive / U	S / PS / U	S / PS / U
4. SOIL DEPTH (In.)	S / PS 48 / U	S / PS 48 / U	S / PS / U	S / PS / U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata Rock)	S / PS clays / U	S / PS clays / U	S / PS / U	S / PS / U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S / PS slow / U	S / PS slow / U	S / PS / U	S / PS / U
7. SOIL PERMEABILITY (Percolation Rate)	S / PS slow / U	S / PS slow / U	S / PS / U	S / PS / U
8. OTHER (Specify)	S / PS / U	S / PS / U	S / PS / U	S / PS / U
9. SITE CLASSIFICATION		Unsuitable	Unsuitable	
SOIL SERIES	Monacan Telena (swamp)	ENON		

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments:

Described By: W. B. Ramsey

Title: Soil Scientist Date: 1-28-80

DHS Form 2601
Sanitation
EHD 539 (3/79)


N
270
206
MONACAN
HELENA
0-2
ENON
2-10
268
WOOD LAND Circle

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 16484
T.C.NO. 025-106-13
MAP DATE
DATE January 31, 1980

NAME OF OWNER Hullis, Charles D.

ADDRESS OF OWNER PO Box 628, Huntersville, NC 28078

LOCATION OF LOT Woodland Circle, Lot 10A, Block B

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive

Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A, .1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R. Adkisson

John R. Adkisson, Environmentalist