Date Received 2/18/80

APT No. 16645

T. C. No. 001-163-06

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Carolina Developers, Inc.
(LAST) (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 1621 E. Boulevard, Suite 2, Charlotte,N.C. ZIP 28203

3) PHONE NO. Home _____ Office 376-3117


4) LOCATION OF PROPERTY 22328 Country Club Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Country Club Shores #3 LOT NO. 6 BLOCK NO. _____

MAP BOOK NO 12 PAGE NO 227

6) DEED REFERENCE: DEED BOOK 2322 PAGE NO. 353

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Carolina Developers, Inc.

By: Duncan L. Harris
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

S.I.R. No. 18645
T.C. No. 001-18300

(Ground Absorption Sewage Disposal)

OWNER: Carolina Developers Inc.
ADDRESS: 1601 E. Rutherford Salisbury
COUNTY: Rowan, NC 28144
LOCATION OF SITE: 22329 County Club Drive

DATE REQUESTED:
PLAT NO: Lot 86
LOT SIZE: 18,450

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-8% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	(S) PS 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (inches) (Impervious strata, Rock)	(S) PS None U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) PS ground water U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (percolation rate)	S (PS) Moderate U	S PS U	S PS U	S PS U
8. OTHER (specify)	S PS Layer sp. f. (U)	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	✓ Provisionally suitable (w/ respect to soils & topography			
10. SOIL SERIES	Cecil			


S - Suitable PS - Provisionally Suitable U - Unsuitable

** See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments: Lot only Area 18,450 Sq. Ft.

Described By: William A. Mayle
Title: Env. Specialist
Date: 2-26-80

DHS Form 2601
Sanitation
EHD 539 (2/80)


80
Country Club Lane
198'
Cecil
212
Terrence Chapel Road
100'