Date Received 9-3-82

MECK COUNTY DEPARTMENT OF HE
SEP - 3 19
ENVIRONMENTAL HEALTH

SIR No. 18978

T. C. No. 041-124-06

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER ALLEN (LAST), MRS. JAMES (FIRST) F. (MIDDLE)

2) ADDRESS OF OWNER Rt. 2, Box 2x, Sherrills Ford, N.C. ZIP 28673

3) PHONE NO. Home 478-2893 Office

4) LOCATION OF PROPERTY 2149 SUNSET BLVD. (STREET OR COUNTY ROAD)


5) SUBDIVISION Sunset Park LOT NO. 303-306 BLOCK NO.

MAP BOOK NO 6 PAGE NO. 675 & 677

6) DEED REFERENCE DEED BOOK 1970 PAGE NO. 103

(7) Please send copy of Test To: M.H. Williams, 13007 CALDWELL RD. CHARLOTTE N.C. 28213

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

X _____
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 4696

PTR No. 18978

Date Issued 9-13-82

T. C. No. 041-124-06

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Allen, (Mrs.) James F.
LAST FIRST MIDDLE

ADDRESS OF OWNER Rt. 2, Box 2-X, Sherrills Ford, NC ZIP 28673

LOCATION OF PROPERTY 2149 Sunset Blvd.
STREET OR COUNTY ROAD

SUBDIVISION LOT NO. 3003-306 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction or installation of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the zoned area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling or construction reducing the indicated area of soil is performed on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and repair of such a system.

This approval is granted based on the Laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William A. Wesler
Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 12978

T.C. NO. 041-12426

(Ground Absorption Sewage Disposal)

OWNER: Rev James F. Allen
ADDRESS: Rt 2 Box 38
Mineola Fork N.C. 28673
LOCATION OF SITE: 3149 Sunset Rd

PLAT NO:
LOT SIZE: 35,283

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-6%	S PS (U) Complex slopes	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-i clay)	S (PS) U Clay	S (PS) U Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U 30-48"	S PS (U) Depth Variable	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	(S) PS U None	(S) PS U None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) PS U >6' to ground water	(S) PS U >6' to ground water	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA	IVA		
9. SITE CLASSIFICATION	Provisionally suitable	unsuitable		
10. SOIL SERIES	Cecil	Dug Pits		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William G. Mendin
Title: Soil Scientist

Date: 9-10-82

EHD 539 (Revised: 6/82)


200'
198'
Cecil
198'
Old Pits
Sunset Blvd
200'