Date Received 5·15·73

APT No 6282

T C No _____

Map Date _____

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Investment Land Sales, Inc.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 1740 E. Independence Blvd. ZIP 28205

3) PHONE NO. Home _____ Office 333-5492


4) LOCATION OF PROPERTY Lot 33, Corner Grovemont Rd. & Bayleaf Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Westwood Forest Additinn LOT NO. 33 BLOCK NO. _____

MAP BOOK NO _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Investment Land Sales, Inc.

May 11, 1973

OWNER Vice President

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. Jun[illegible] 1973
2. _____
3. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. 6282
T.C. No. P.O. 153-143-16
11-10-72

NAME OF OWNER Investment Land Sales, Inc.

ADDRESS OF OWNER 1740 East Independence Blvd. ZIP 28205

LOCATION OF LOT Grovemont Road & Bayleaf Lane, Lot 33

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	8-1-72	28.4 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

L R Barnes
Environmentalist

(Stencil No.)
HHD 398
a/71

FORM NO.
E-19-8-14-70