Date Received 2 Jun 83

FEB 2 1983

ENVIRONMENTAL HEALTH

ICAR(S) Application No. 20337

T. C. No. 048-0115

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.

3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4) No of Bedrooms 3
5) Business Use — Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ___ Yes ✓ No
9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System
1. Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No. ___
12) VA Case No. ___

13) NAME OF OWNER Morrison (LAST) James (FIRST) (MIDDLE)
14) ADDRESS OF OWNER 6200 Carver Blvd 28213
15) PHONE NO. Home 598-8653 Office -
16) LOCATION OF SYSTEM SAME (STREET OR COUNTY ROAD)
17) SUBDIVISION Rockwell Park Lot No. 56-57-58 Block No. ___
Map Book No. ___ Page No. ___
18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___
19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___
20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

2 Jun 83
DATE OF APPLICATION

James J Morrison
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

BT 12-7-83

Date Issued 12-6-83

Serial No. 7029

SIR No. 20337

T. C. No. 043-011-15

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Morrison, (LAST) James (FIRST) (MIDDLE)

ADDRESS OF OWNER 6200 Carver Blvd., Charlotte, NC ZIP 28213

LOCATION OF LOT 6200 Carver Blvd. (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 20337. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

*** USE EXISTING SYSTEM ***

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 20837
TC: 043-011-15
SERIAL: № 15289 ☒ L ☐ CRT

JOB LOCATION

① ADDRESS: 6302 49 Carver Blvd (STREET NO. / STREET) ② FILE:

③ JURISDICTION: ④ TAX PARCEL NO.:

⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: Earnestine Watson (FIRST) (MIDDLE) (LAST)

⑨ MAILING ADDRESS: 6302 Carver Blvd

⑩ CITY: Charlotte ⑪ STATE: N.C. ⑫ ZIP: 28213

⑬ PHONE: (WORK) 542-2218 ⑭ (HOME) 332-4451

REQUEST

This request is for a(n):

⑮ ☐ New permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☒ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 2 ㉕ Type?

㉓ Maximum occupancy? 4 ㉖ Maximum number of employees?

㉔ Basement? ☒ yes ☐ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Earnestine Watson

Date: 4/11/1988

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until a(n) Installation, Construction, Alteration and/or Repair permit is issued by the Department.

. . . This permit is not transferable, and shall become null and void 3 months from the date of issuance.

Environmentalist Date

Director or Authorized Section Head Date

*This permit must be signed by the Director of Environmental Health or authorized section head in order to be valid.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 20337 DATE: 1-15-88

TC: 043-011-15 ☐ L

SERIAL № 11541

Permission is hereby given to ____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 1-11-88 . All work shall be completed on or before 2-15-88, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank repair gallons

Liquid Capacity of Dosing Tank ____ gallons

Tank Construction RCC

Absorption and/or Nitrification Lines:

Trench Width 12 feet

Total Line Length 140 feet

Number of Lines 4

Depth of Stone 17 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well 750 feet

NAME OF OWNER Earnestine Watson

LOCATION OF PROPERTY 6302 Tanner Blvd.

Comments: 1 bed 12'X35'X17" stone

Division or Section Head

B. R. Ferguson
Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 20337 DATE: 2-11-88

TC: 043-011-15 ☒ L ☐ CRT

SERIAL № 10859

Name of Owner Earnestine Watson Juris.:

Address of Property 6302 Carver Blvd

Inspection Data:

Tank Material repair

Total Length of Drainfield 140'

Number of Lines 4 @ 35'

Cover Depth 24"

Water Supply Source well

Distance to Water Source 750'

Excavation Inspected 2-11-88

Tank(s) Inspected

Wash Line Inspected

High Water Alarm Inspected

PLOT

Design: 1988 septic repair CTR# 103

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☒ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS:

B.A. Ferguson Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20338

T.C. NO. PO 135-211-22

(Ground Absorption Sewage Disposal)

OWNER: Bob McLemore Co.
ADDRESS: PO Box 25946
Charlotte, NC 28212
LOCATION OF SITE: 5927 Gold Wagon Lane

PLAT NO: L75-W
LOT SIZE: 22,432

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-10% U	S PS complex slopes U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS clay U	S PS clay U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS Blocky U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS 36-40" U	S PS < 30" U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS > 36" U	S PS < 30" U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS > 36" to ground water U	S PS Eroded Areas channel runoff U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	1UA	1UA		
9. SITE CLASSIFICATION	provisionally suitable	unsuitable		
10. SOIL SERIES	Cecil Little	complex slopes		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William R. Morris
Title: Soil Scientist

Date: 12-15-83

EHD 539 (Revised: 6/82)


Gold Wagon Lane
170'
169'
208'
complex slopes
89'