Date Received 11-2-83

RECEIVED
NOV 7 1983
ENVIRONMENTAL HEALTH

SIR No. 20252
T. C. No. 053-092-19
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Poole (LAST) Richard (FIRST) E - (MIDDLE)

2) ADDRESS OF OWNER RFD 5 Box 1019-M ZIP 28214

3) PHONE NO. Home 399-6550 Office 399-4448 ext 21 Wesleyne


4) LOCATION OF PROPERTY ~~Hoffman Rd~~ RD Harris Mapp Rd.
STREET OR COUNTY ROAD

5) SUBDIVISION _____ LOT NO. 15 BLOCK NO. _____

MAP BOOK NO. 053-092-19 PAGE NO. _____

6) DEED REFERENCE: DEED BOOK 4485 PAGE NO. 541

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

CC Richard E. Poole
OWNER

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20252
T.C. NO. PO 053-092-19
DATE: November 30, 1983

Richard E. Rorie
Rt. 5, Box 1019-M
Charlotte, NC 28208

Re: Property located at Hawfield Road, Plat #15

Dear Mr. Rorie:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20252

T.C. NO. AD 053-0274

(Ground Absorption Sewage Disposal)

OWNER: Richard E. Rose
ADDRESS: Rt. 5, Box 1019-M Charlotte, N.C. 28269
LOCATION OF SITE: Waxhaw Rd

PLAT NO: #15
LOT SIZE: 1 Acre

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-8%	S (PS) U 2-8%	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U clay	S (PS) U clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U 36-40"	S PS (U) 30-36"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U >36"	S PS (U) <36"	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U >36" to ground water	S (PS) U 7-36" to ground water	S PS U	S PS U
7. OTHER (Specify)	S PS U Limited Area	S PS U	S PS U	S PS U
8. SOIL GROUP	IV A	IV A		
9. SITE CLASSIFICATION	Provisionally Suitable	Unsuitable		
10. SOIL SERIES	Cecil-Lilly	Pacolet-Lilly		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments: Recommend plans for system & structure locations be submitted

Described by: William A. Mullis
Title: Sanitarian

Date: 1-25-83

EHD 539 (Revised: 6/82)

1E


60'
Paralet-
Cecil-like
300'
300'
60'