Date Received 5-6-83

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 6 1983
ENVIRONMENTAL HEALTH

SIR No. 19643
PCN 049-093-22
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER JARRETT (LAST) & ASSOCIATES (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 6535 CROC SAVANNAH ZIP 28212

3) PHONE NO. Home 568-3303 Office SAME


4) LOCATION OF PROPERTY BRANCHHALL CIR. (STREET OR COUNTY ROAD)

5) SUBDIVISION GLEN ECHO PARK LOT NO 10 BLOCK NO. 2

MAP BOOK NO. 8 PAGE NO. 439

6) DEED REFERENCE DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Jarrett & Assoc.
OWNER
by: James G. Jarrett

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19643

T.C. NO. PO 049-09322

(Ground Absorption Sewage Disposal)

OWNER: Garrett & Associates
ADDRESS: 1535 Old Savannah Rd. Charlotte, NC
PLAT NO: 41 10
LOT SIZE: 14,895
LOCATION OF SITE: Brentwood Circle

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 10-20%	S (PS) U — 2 - 12%	S (PS) U — 10-20%	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U — clay	S PS U — Mixed sandy loam clay	S (S) PS U — sandy loam	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — blocky	S PS (U) — massive	S PS (U) — massive	S PS U
4. SOIL DEPTH (inches)	S (PS) U — 30-40"	S PS (U) — 24"+ Fill	S PS (U) — saprolite @ soil surface	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — saprolite 30"	S PS (U) — compacted Fill	S PS (U) — saprolite @ soil surface	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — 30" to ground water	S (PS) U — 30" to ground water	S (PS) U — 30" to ground water	S PS U
7. OTHER (Specify)	S PS (U) — Restricted Area	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA	IVA	IVA	
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	
10. SOIL SERIES	Cecil/Lilly	Fill	Cut Area	

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William A. Medlin
Title: Soil Scientist
Date: 5-16-83

EHD 539 (Revised: 6/82)

2/


85'
CUT
100
199'
Centerline
Fill
85

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

SIR. NO. 19643
T. C. NO. PO 049-093-22
DATE: 5-17-83

Jarrett & Associates
6535 Olde Savannah Road
Charlotte, NC 28212

Re: Property located at Birchhill Circle, Lot 10

Dear Mr. Jarrett:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, please submit your proposals, in the form of plans and specifications, to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of a "Septic Tank Agreement Form" provided by this office.

If I may be of assistance, please feel free to call at any time.

Sincerely,

for John McAdkisson
Michael A. Sexton
Environmentalist
On Premises Waste Disposal Section

Enclosure

EHD #37 (11-82)

Mecklenburg County

Department Of Building Standards And Code Enforcement

P. O. Box 31097

Charlotte, North Carolina 28231-1097

May 3, 1983

To: Environmental Health
1200 Blythe Blvd

Reference: Mobile Home Site

Dear Inspector

The parcel of land located at 15826 E. Rocky River Rd and further identified by tax parcel number 007-231-09 is zoned RU (Rural).

Permitted uses in this district include: Mobile Homes on individual lots.

If this office can be of any further assistance, please contact us.

Very truly yours,

Robert Caddell
Zoning Inspector