

14010 CLARENDON POINTE CT

00101481

12/19/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CLARENDON POINTE COURT

793B/8664A

File # 6484A

Site Plan
Lot 15
1"=20'

100' — Future repair Not Engaged

orange — d-box w/speed leveler — 75gal wastewater — Septic tank — Conventional 3x100

white — "

blue — "

red — "

100' Repair orange — T-P Paver Block

10' setback

50' Repair

50' Repair

2" sch 40 PVC supply line

1500gal ST

1000gal Pump TANK

22W

30'

3 bedroom house

63'±

Pump cycle ~20GPM
run time 9 mins.
2 doses/day set by floats to tank

Total head 25'
Use MEAD Myers Pump

LAKE NORMAN

1"=20'