Date Received 8/9/79

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 6 1979
ENVIRONMENTAL HEALTH

APT No. 16031

T. C. No. 063-095-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Tucker (LAST) Michael (FIRST) L. (MIDDLE)

2) ADDRESS OF OWNER 8418 Pine Circle Charlotte ZIP 28215

3) PHONE NO. Home 537-8791 Office —


4) LOCATION OF PROPERTY Riverview Drive (STREET OR COUNTY ROAD)

5) SUBDIVISION Riverview Acres LOT NO. 4 BLOCK NO. D

MAP BOOK NO 8 PAGE NO. 321 and 323

6) DEED REFERENCE DEED BOOK 3655 PAGE NO. 0134

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



1) ACCURATELY DIAGRAM & DIMENSION LOT

Michael L. Tucker
OWNER

EHD-5-76

Environmental Health Department's Copy

Area I

S. I. R. NO. 16031

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 003-085-07

(Ground Absorption Sewage Disposal)

OWNER: MICHAEL TUCKER
ADDRESS: 8418 PINE Circle
COUNTY: CHARLOTTE 28215
LOCATION OF SITE: RIVERVIEW Dr. LOT 4

DATE REQUESTED: 8-9-79
PLAT NO.:
LOT SIZE: 20250 (.45A)

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS (2-70) U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, note 2:1 Clay)	S PS (U) MIXED w/ clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS (U) Massive	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS (<48) U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS (U) Saprolite	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S PS (U) slow	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS (U) slow	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable			

SOIL SERIES: WILKES

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.


Recommendations/Comments: THIS ONE IS RIDICULOUS.

Described By: W. B. Ramsey

Title: Soil Scientist Date: 8-15-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

2


RIVER-VIEW DRIVE
150
WILKES-2-10
WILKES
12-70
135

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. No. 16031
T.C. No. 023-085-07
MAP DATE
DATE 8/16/79

NAME OF OWNER Tucker, Michael L.

ADDRESS OF OWNER 8418 Pine Circle, Charlotte, NC 28215

LOCATION OF LOT Riverview Drive, Riverview Acres subdivision LOT 4 BLK. B

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system due to the following reasons:

Soil Structure Massive
Soil Permeability Unsuitable

John R. Atkisson

John R. Adkisson, Environmentalist