

Henderson Cir.

1/29/08

thomatc

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

Date Received 2-27-84

MECK COUNTY DEPARTMENT OF
RECEIVED
FEB 27 1984
ENVIRONMENTAL HEALTH

SIR No. 20658

T. C. No. 037-212-14

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Tyson (LAST) Franklin (FIRST) A. (MIDDLE)

2) ADDRESS OF OWNER 126 Starmount Ave. ZIP 28213

3) PHONE NO. Home 596-5932 Office 597-7790


4) LOCATION OF PROPERTY [redacted] Henderson Circle (STREET OR COUNTY ROAD)

5) SUBDIVISION Trexler Height LOT NO. 72-75 BLOCK NO.

MAP BOOK NO 4 PAGE NO. 641

6) DEED REFERENCE: DEED BOOK 3784-263 PAGE NO. 3796-077

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Franklin A. Tyson
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20658

T.C. NO. 037-212-14

(Ground Absorption Sewage Disposal)

OWNER: Franklin A. Tyson
ADDRESS: 126 Starmount Ave. Charlotte, N.C. 28213
PLAT NO:
LOT SIZE: 29,000
LOCATION OF SITE: Henderson Co.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 8-15% / PS / U	S / PS / U	S / PS / U	S / PS / U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S 2-1 / PS Clay / (U)	S / PS / U	S / PS / U	S / PS / U
3. SOIL STRUCTURE (12-36 inches)	S / (PS) Blocky / U	S / PS / U	S / PS / U	S / PS / U
4. SOIL DEPTH (inches)	S / (PS) 36-40" / U	S / PS / U'	S / PS / U	S / PS / U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S 36" / (PS) / U	S / PS / U	S / PS / U	S / PS / U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S Perched / PS water / (U) table	S / PS / U	S / PS / U	S / PS / U
7. OTHER (Specify)	S 18-20" / PS / U	S / PS / U	S / PS / U	S / PS / U
8. SOIL GROUP	1UB			
9. SITE CLASSIFICATION	unsuitable			
10. SOIL SERIES	Helena-Urban Land			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: William R. Marks
Title: Soil Scientist

Date: 3-24-84

EHD 539 (Revised: 6/82)

24


Henderson Rd.
gravel Rd
492'
Helena-
Lima
60'
60'
Stream
492'

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20658
T.C. NO. 037-212-14
DATE: 3-5-84

Franklin A. Tyson
126 Starmount Avenue
Charlotte, NC 28213

RE: Property located at Henderson Circle, Lots 72-75

Dear Mr. Tyson:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,
Willard B. Ramsey for
Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure