

2502 BRIAR TRAIL CT

21512204

5/29/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

APPLICATION FOR AN IMPROVEMENT PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 4995A
TC: _____
SERIAL: No 17716

See file 4781A for change slip

☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 2502 BRIAR TRAIL COURT (STREET NO. / STREET) ② FILE: 4995A

③ JURISDICTION: MORNINGSTAR TOWNSHIP ④ TAX PARCEL NO.: 215 121 11 PO

⑤ SUBDIVISION: BLACKBERRY RIDGE, PHASE II ⑥ LOT: 55 ⑦ BLOCK: _____

OWNER

⑧ NAME: DAN (FIRST) L. (MIDDLE) MOSER CONSTRUCTION + REALTY CO., INC. (LAST)

⑨ MAILING ADDRESS: 2101 SARDIS ROAD N., SUITE 110

⑩ CITY: CHARLOTTE ⑪ STATE: NC ⑫ ZIP: 28227

⑬ PHONE: (WORK) 845-1378 ⑭ (HOME) 845-1293

REQUEST

This request is for a(n):

⑮ ☑ New permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type? _____

㉓ Maximum occupancy? 5 ㉖ Maximum number of employees? _____

㉔ Basement? ☐ yes ☑ no ㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☑ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter on the property for the purpose of processing this request.

Signed: Dan L Moser

Date: 2/3/89

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 36 months from the date of issuance.

_____ / _____
Environmentalist Date

_____ / _____
Director or Authorized Section Head Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.


PROPOSED PLOT PLAN

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 4995 A

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



2502 BRIAR TRAIL COURT
LOT # 55
PHASE II

Signed: Dan L Moser

Date: 2/3/89

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

October 7th, 1988

Dan L. Moser Construction
2101 Sardis Road North, Suite 110
Charlotte, NC 28212

RE: Property located at 2502 Briar Trail Court 55
FILE: 4995A
PARCEL: 21512111 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 15617) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure (2)

APPLICATION FOR SOIL INVESTIGATION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 4995A

TC: _____

☐ PC ☐ REPT

ENVIRONMENTAL HEALTH DIVISION
PAID
SEP 8 1988
P. Karrel

JOB LOCATION

① ADDRESS: 2502 BRIAR TRAIL COURT

② SUBDIVISION: BLACKBERRY RIDGE ③ LOT: 55 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 22 PAGE NO.: 599 PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: D.B. 116 + 153 PAGE NO.: 125 + 519

OWNER


⑦ NAME: DAN (FIRST) L. (MIDDLE) MOSER CONSTRUCTION & REALTY CO., INC. (LAST)

⑧ MAILING ADDRESS: 2101 SARDIS ROAD N., SUITE 110

⑨ CITY: CHARLOTTE ⑩ STATE: NC ⑪ ZIP: 28212

⑫ PHONE: (WORK) 847-9027 (HOME) 821-7820

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Dan L Moser

Date: 9-2-88

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 15617

File: 4995A Action 2

Parcel: 21512111 PO ☐ PC

Location: 2502 Briar Trail Court

Subdivision:


Lot: 55 Block: Acres: 40

Owner: Dan L. Moser Construction
Address: 2101 Sardis Road North, Suite 110
Charlotte, NC 28212

Comments: _____

Described by: W. B. Ramsey

Date: 10 — 6 — 87



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2–4	S (PS) U 2–5	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Structure	S PS (U)	S (PS) U	S PS U	S PS U	S PS U	S PS U
Drainage	S PS (U)	S (PS) U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 30–42	S PS (U) 30"	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Available Space	S PS U limited *	S PS (U)	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS (U) Fill	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	~~IIb~~ Filled Ditch	~~IIa~~ 1-1 Clayey				
Area Classification	S PS (U)	S PS (U)	S PS U	S PS U	S PS U	S PS U