Date Received 3-15-83

SIR No. 19446

T. P. No. 225-041-11

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Wallace (LAST) Reginald (FIRST) Steven (MIDDLE)

2) ADDRESS OF OWNER 5807 E Sharon Rd Charlotte ZIP 28210

3) PHONE NO. Home 552 9049 Office 542 6025


4) LOCATION OF PROPERTY ~~Providence Rd~~ Lot Elm LANE W. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 7 BLOCK NO. _____

MAP BOOK NO 225 PAGE NO 04

6) DEED REFERENCE: DEED BOOK 4251 PAGE NO 697

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Reginald Wallace
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 4922

PTR No. 19446

T. C. No. PO 225-141-11

Date Issued 3-31-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Wallace (LAST) Reginald (FIRST) Steven (MIDDLE)

ADDRESS OF OWNER 5807 E. Sharon Rd., Charlotte, NC ZIP 28210

LOCATION OF PROPERTY Providence Road West (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. 7 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit for installation and operation of the proposed system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction. Plans and specifications of the wastewater treatment system on the said lot
2. The size of the septic tank and wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health in accordance with the permeability rate obtained above, and on the size and type of building or building to be served.
3. This approval is given only for the system location and the area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading [illegible] including the drilling of a well, is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable. The installation, construction, alteration or the repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

Willard B. Ramsey
Soil Scientist
EHD-S-76

Mike Sutton
Environmental Health Director or
Authorized Section Head

Environmental Health Department's Copy

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19446

T.C. NO. P0225-041-11

(Ground Absorption Sewage Disposal)

OWNER: Reginald Steven Wallace
ADDRESS: 5807 E SHARON Rd 28210

PLAT NO:
LOT SIZE: Lot

LOCATION OF SITE: Providence Rd West

Lot 7

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-5 U	S (PS) 2-5 U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) Clayey U	S PS (U) mixed clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS (U) weak Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 40-48' U	S PS (U) 10-30	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) None U	S PS (U) clay	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) Adequate U	S PS (U) Slow	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IIa	IIb		
9. SITE CLASSIFICATION	P. Suitable	Unsuitable		
10. SOIL SERIES	Cullen	Mecklenburg		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William B. Ramsay
Title: Soil Scientist

Date: 3-23-88

EHD 539 (Revised: 6/82)


Elm Lane West
450
Cullen
Disturbed
100
200
Area II
Predominately
MecKlenburg
Unsuitable
618
800
700