

3301 BACK CREEK CHURCH RD

05119127

6/17/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

LX100

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 10842 DATE: 10-15-93

TC: 051-191-04 PO ☐ L ☒ CRT

SERIAL Nº 15735

Name of Owner Charles Sossamon Juris.:

Address of Property 3301 Back Creek Church Rd.

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400'

Number of Lines 5 @ 80' each

Cover Depth 6-12"

Water Supply Source well

Distance to Water Source 52'-55' at nearest point of drainline (solid pipe 50'+ from well)

Excavation Inspected 10-15-93

Tank(s) Inspected 10-15-93

Wash Line Inspected ———

High Water Alarm Inspected 10-15-93

Balance of file in microfilm

PLOT

Nathan Osborne

Design: 1993, 1500 gal, 1000 gpt, 1200 sq ft drainfield at 5 lines at 3'x80'x12" stone CTR# 70
½ hp Gould pump WS05511A, cecil, 31' from center of road.

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired
☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 3 bdrm home

Type III-b.

Susan Patterson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.