C of A (s) No. 21628

Date Issued 11-26-84 **Serial** 7119 T. C. No. 059-092-02 L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Stone (LAST) Robert (FIRST) (MIDDLE)

Location of Property 2029 Toddville Rd.

Application Number — Permit Number —

Inspection Data:

Liquid Capacity of Tank 1250 gal Tank Material

Total Length of Drain Tile 100' Number of Lines 3

Depth of Filter Material 17" Cover Depth 12"

Water Supply Source well Distance from Water Source 750'

Excavation Inspected 11-26-84 (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 11-26-84 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

D. R. Ferguson
Environmentalist

EHD-5-76

Environmental Health Department

Date Issued 11-23-84

Serial No. 07729


ICAR(S) Permit No. 21628

T. C. No. 059-092-02

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21628, dated 11-14-84 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 12-23-84, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate Agua

Liquid Capacity of Tank ____

Tank Construction ____

Absorption and/or Nitrification Lines:

Total Line Length 100'

Number of Lines 3

Distance from House 5'

Distance from Property Line 10'

Distance from Well 750

NAME OF OWNER Robert Stone

LOCATION OF PROPERTY 2029 Todd Mill Rd

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Inst 9" Trench System Effluent Disp

Comments: ____

Division or Section Head

B. K. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

Date Received 11-16-84

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
SEE INSTRUCTIONS ON BACK
RECEIVED
NOV 16 1984
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 21628

T. C. No. 059-091-02?


Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ... Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ... Yes ... No ✓
Residence ✓ Yes ... No
4) No of Bedrooms ... 2
5) Business Use — Max No Employees ... ✓
6) Washing Machine ... ✓ Yes ... No
7) Garbage Disposal ... Yes ... ✓ No
8) Dishwasher ... Yes ... ✓ No
9) Water Supply
A) Individual Well ... ✓
B) Governmental System ...
C) Community System
1. Well source ...
2 Governmental source ...
10) Sewage System
House located within 200 feet of public sewer ... Yes ... ✓ No
House located within 200 feet of community sewer ... Yes ... ✓ No
11) FHA Case No ...
12) VA Case No. ...

13) NAME OF OWNER Stone (LAST) Robert (FIRST) Howard (MIDDLE)

14) ADDRESS OF OWNER 10029 Sawmill Rd 28210

15) PHONE NO. Home 588-6986 Office 399-1364

16) LOCATION OF SYSTEM 2079 Saddleridge Rd (STREET OR COUNTY ROAD)

17) SUBDIVISION Louis Forest Lot No ... Block No. ...

Map Book No. ... Page No. ...

18) DEED REFERENCE — DEED BOOK ... AT PAGE ...

19) HAS A SOIL INVESTIGATION BEEN RUN? L YES ... NO DATE RUN 1952

20) PTR NUMBER (See Instructions) ...

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

11-14-84
DATE OF APPLICATION

Robert H Stone Jr
OWNER

EHD-S-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. [illegible]

T.C. NO. [illegible]

(Ground Absorption Sewage Disposal)

OWNER: Lucille Mercado
ADDRESS: 126 Ivanhoe Church Rd
Charlotte, NC 28213

PLAT NO: Lot 13
LOT SIZE: 4 acs

LOCATION OF SITE: 126 Ivanhoe Church Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-10% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS Some U Clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS 36"+ U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS 24" U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S Perched PS U 24"+	S PS U	S PS U	S PS U
OTHER (Specify)	S Rock Outs PS None U	S PS U	S PS U	S PS U

7. SOIL GROUP: II A

8. SITE CLASSIFICATION: [illegible]

10. SOIL SERIES: [illegible]

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Manual on Evaluation (includes soil profile, slope, [illegible] roots, streams, surface wet areas, fill areas, wells, water courses, stones)

Recommendations/Comments:

Described by: [illegible]
Title: [illegible]

Date: [illegible]