

14617 N C 73 HY

00102107

5/31/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5317A DATE: 5/19/89

TC: 001-021.07 ☒ L ☒ CRT

SERIAL № 11880

Name of Owner Blythe NAN. L. Juris.:

Address of Property 14617 N.C. Hwy 73

Inspection Data:

Tank Material Pcc

Total Length of Drainfield 400'

Number of Lines 4 @ 100'

Cover Depth 24"

Water Supply Source well

Distance to Water Source 100'

Excavation Inspected 5/19/89

Tank(s) Inspected 5/19/89

Wash Line Inspected

High Water Alarm Inspected

PLOT

Design: 1989 1500 St, Sm. 1200SFT, 12"S, Excl CTR# 22

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ Installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for 3 bedroom home

Judy J. Kuei R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH


1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5317A DATE: 5/17/89

TC: 001-021-07 ☐ L

SERIAL Nº 12693

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5/23/89. All work shall be completed on or before 6/17/89, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank _____ gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400 feet

Number of Lines 4

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well 100' feet

NAME OF OWNER Blythe NAN. L.

LOCATION OF PROPERTY 14617 N.C. Hwy 73

Comments: INSTALL 4 Trenches 3' x 100' 12" Stone, Straw Cover.

Division or Section Head

Environmentalist Judy J. Kerr RS

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 1/30/89

Name/Company Dan L. Blythe

Sanitation ____

Vector Control ____

C.P.W.D. ✓

Service: Imp Dust
#5317A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

JAN 30 1989

Fee: $ 150 —

CR# 3843
#150.00

Completed by

Collected by

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 5317A
TC: _____
SERIAL: Nº 15366
☒ ☐ CRT

JOB LOCATION

① ADDRESS: 14617 (STREET NO.) N.C. Hwy 73 (STREET) ② FILE: 5317-A

③ JURISDICTION: _____ ④ TAX PARCEL NO.: 001-021-07

⑤ SUBDIVISION: _____ ⑥ LOT: _____ ⑦ BLOCK: _____

OWNER

⑧ NAME: Nan. (FIRST) L. (MIDDLE) Blythe (LAST)

⑨ MAILING ADDRESS: 14617 N.C. Hwy. 73

⑩ CITY: Huntersville ⑪ STATE: N.C. ⑫ ZIP: 28078

⑬ PHONE: (WORK) 875-4439 ⑭ (HOME) 875-6886

REQUEST

This request is for a(n):

⑮ ☒ New permit

⑯ ☐ Repair or alteration permit

⑰ ☐ Authorization for mobile home exchange

⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home

㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3

㉕ Type? _____

㉓ Maximum occupancy? 6

㉖ Maximum number of employees? _____

㉔ Basement? ☐ yes ☒ no

㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: X Nan L. Blythe

Date: X 1-23-89

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

L.A. Station required

Environmentalist 2-8-89 Date

Director or Authorized Section Head 2-9-89 Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.

PROPOSED PLOT PLAN


MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5317 A

TC: 001 - 021 - 07

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Old House To be Moved
New one Built

Signed: X Nan L Blythe

Date: X 1-23-89

Mecklenburg County
Health Department

Basil G. Deltu, M.D., M.P.H.
Health Director

January 13th, 1989

Nan L. Blythe
14617 NC Hwy. 73
Huntersville, NC 28078

RE: Property located at 14617 NC Hwy 73
FILE: 5317A
PARCEL: 00102107

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 15868) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 15868

File: 5317A Action 4

Parcel: 00102107 ☐ PC

Location: 14617 NC Hwy 73

Subdivision:


Lot: Block: Acres: .89

Owner: Nan L. Blythe
Address: 14617 NC Hwy. 73
Huntersville, NC 28078

Comments: Lift Station May be Required.
Well Not Located
House To Be Moved - New one Built

Described by: W. B. Ramsey

Date: 1-12-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-8	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 44-48	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space 1E Adequate 3BR Old Lot	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVa Cecil					
Area Classification	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 1/5/89

Name/Company Dan L. Blythe

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: Soil Test
#5317A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
~~ENVIRONMENTAL HEALTH DIVISION~~
PAID

JAN 5 1989

Fee: $30 -

Completed by

Collected by

APPLICATION FOR SOIL INVESTIGATION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5317A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 14617 N. C. Hwy. #73

② SUBDIVISION: _____ ③ LOT: _____ ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 001 PAGE NO.: 021 PARCEL NO.: 07

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER

⑦ NAME: Nan (FIRST) L. (MIDDLE) Blythe (LAST)


⑧ MAILING ADDRESS: 14617 N.C. Hwy #73

⑨ CITY: Huntersville ⑩ STATE: N.C. ⑪ ZIP: 28078

⑫ PHONE: (WORK) 704 - 875-4000 (HOME) 704 - 875-6886

⑬ Accurately diagram and dimension lot.

The existing house is to be removed and a new residence built if system is approved.



Septic System in Back of Existing House.

New system to be installed in front if approved.

⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Mrs Nan L. Blythe

Date: December 26, 1988

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY