Date Received 8-15-83

SIR No. 19943

T. C. No 023-055-18

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER WILLIAMS (LAST) RUBE (FIRST) W. (MIDDLE)

2) ADDRESS OF OWNER 322 TODDVILLE RD ZIP 28208

3) PHONE NO. Home 399-7012 Office 399-7012


4) LOCATION OF PROPERTY Route 9 Box 10 NC 28214 River Cir
(STREET OR COUNTY ROAD)

5) SUBDIVISION Riverview Acres Extension LOT NO 475 BLOCK NO. K

MAP BOOK NO 9 PAGE NO 57

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Ruby N. Williams Carl Williams
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 19943
T.C. NO. 023-085-18
DATE: 8-22-83

Mr. Rube W. Williams
322 Toddville, Road
Charlotte, NC 28208

Re: Property located at River Circle, Lots 4 & 5, Blk. K

Dear Mr. Williams:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

for Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 12943

T.C. NO. 023-085-B

(Ground Absorption Sewage Disposal)

OWNER: Mike H. Williams
ADDRESS: 322 Tadlock Road
Charlotte NC 28206

PLAT NO: 125415 BK
LOT SIZE: 2 acres

LOCATION OF SITE: [redacted] Carol
Rinn

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 10-20%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S Loam PS U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S 12-36" PS U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S Saprolite @ 18-36" PS (U)	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) >36" to ground water U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS Site plan U	S PS U	S PS U	S PS U
8. SOIL GROUP	II-A			
9. SITE CLASSIFICATION	Unsuitable			
10. SOIL SERIES	—			

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Per Julie's Morning report
Lot was originally evaluated on 3-23-83 was changed in
new report to 1 AM - 3-23-83

Described by: William R Madison
Title: Soil Scientist

Date: 5-9-83

EHD 539 (Revised: 6/82)


150'
176'
A-C soils
149'
130'
River

Date Received 8-15-83

RECEIVED
AUG 1 : 1983
ENVIRONMENTAL HEALTH

CAR(S) Application No. 19943

T C No 623-085-18


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) X Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___Yes ___No
Residence X Yes ___No

4) No of Bedrooms 2
5) Business Use — Max No Employees ___
6) Washing Machine X Yes ___No
7) Garbage Disposal ___Yes X No
8) Dishwasher ___Yes X No
9) Water Supply
A) Individual Well X
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___Yes X No
House located within 200 feet of community sewer ___Yes X No
11) FHA Case No ___
12) VA Case No. ___

13) NAME OF OWNER WILLIAMS (LAST) RUBE (FIRST) W. (MIDDLE)

14) ADDRESS OF OWNER 322 TODDVILLE RD., CHARLOTTE, N.C. 28208

15) PHONE NO. Home 399-7012 Office NONE

16) LOCATION OF SYSTEM ROUTE 9 CHARLOTTE, N.C. RIVER CIRCLE ACRES EXT. (STREET OR COUNTY ROAD)

17) SUBDIVISION RIVERVIEW Lot No. 4+5 Block No. K

Map Book No. 9 Page No. 57

18) DEED REFERENCE — DEED BOOK ___ AT PAGE 155-156

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES X NO DATE RUN ___

20) PTR NUMBER (See Instructions) NONE

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

8-10-83
DATE OF APPLICATION

Rube W. Williams, Carl. Williams
OWNER

BHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 19943

TC: 023-085-18

☐ PC ☐ REPT

RECEIVED
MECKLENBURG COUNTY HEALTH DEPT.
JAN 14 1...
ENVIRONMENTAL HEALTH DIVISION

JOB LOCATION

① ADDRESS: 7516 River Circle Charlotte, N.C.

② SUBDIVISION: Riverview Acres Extension ③ LOT: 4 & 5 ④ BLOCK: K

⑤ PARCEL REFERENCE: BOOK NO.: 023 PAGE NO.: 085 PARCEL NO.: 18

⑥ DEED REFERENCE: BOOK NO.: 4425 PAGE NO.: 818

OWNER

⑦ NAME: Donald (FIRST) E (MIDDLE) Jones (LAST)


⑧ MAILING ADDRESS: 300 Iverson Way

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28203

⑫ PHONE: (WORK) 704-388-2360 (HOME) 704-527-4573

⑬ Accurately diagram and dimension lot.

copy mailed
1/14/88 SR



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Donald E Jones

Mecklenburg County services are available without regard to ...ethnic origin, sex, or disability

Date: DECEMBER 10, 1987

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

PROPOSED PLOT PLAN


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 19943

TC: 023-085-18

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: Donald E. Jones

Date: February 6, 1988

Mecklenburg County
Health Department

Basil G. Drita, M.D., M.P.H.
Health Director

June 23, 1988

Donald E. Jones
300 Iverson Way
Charlotte, NC 28203

Dear Mr. Jones:

RE: Property located at 7516 River Circle
FILE: 19943
PARCEL: 023-085-18

Receipt of your plans for a modified waste disposal system for the property referenced above is acknowledged.

Your plans for the modified system for the above property as submitted are approved. The well shall not be located closer than 50 feet away from any part of the system or the repair area. Micro flush toilets will be required for all bathrooms.

Upon execution and recording with the Register of Deeds Office, Mecklenburg County, of the enclosed "Septic Tank Agreement Form", an Improvements Permit may be issued by this office.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

SDD/ir

Enclosures - 3 Septic Tank Agreement Forms
Copy of Plans

19 APR 85

7516 LOOP CIRCLE

PG 1 OF 3

E. BALCOM

[illegible] 360 GPD/[illegible] [illegible]

ALLOW 35% [illegible] WATER

360 x .35 = 126 GPD

360 x .65 = 234 GPD

⇒ [illegible]

- USE 75 GAL/DAY
- 126 GPD ÷ 0.30 GAL/SF = 420 SF

420 SF ÷ 3 SF/FT = 140 FT LEACH LINE

∴ NEED 2 AREAS 140' x 9' OR 70' x 15'

⇒ FOR [illegible]

- USE 1500 GAL ST. TANK
- 2.4 GPD/SF x .10 M/DAY = 146 SF

146 SF ÷ 5 SF/FT = 292 FT TRENCH

∴ USE 4 LINES 40 FT EACH

NEED 2 AREAS 128' x 15'

ISAFC 83

7516 INLET PIPE

PAGE 1 OF 3

LPC DESIGN

E. CANADA

* USE [illegible] 6.7' O.C.

- 42 FT ÷ 6.7' = 7 HOLES/LATERAL > 42 HOLES
- AT 100 GPM/HOLE, FROM TABLE 2, FLOW 2.5 GPM/HOLE
- 42 HOLES × 2.5 GPM/HOLE = 21 GPM
- HEAD LOSS AT
  - PIEZOMETRIC [illegible] = 0 FT
  - FRICTION HEAD = FROM TABLE 3, 100' OF FOR 1½ PVC 2.7 FT/100' × 1.2 CA = 4'
  - ELEVATION HEAD = 0
  - TOTAL HEAD = 7 FT
- FOR 21 GPM AT 7 FT, USE AQUAMATIC CHECK CHARGER OF 22 GPM @ 10 FT
- LOCATION VOLUME, [illegible]
  - 6 LINES × 42 FT/LINE × 9 GAL/100 FT = 23 GAL
  - CA 100 FT SUPPLY 2" [illegible] × 9 GAL/100 FT = 9 GAL
  - TOTAL 141 GAL USE 150 GAL
- CHECK VALVE: MODEL [illegible]
- ¼" SCHED 40 PVC WELL, [illegible]

* MODIFY HOLE SPACING TO FIT ELOFF SITE

3 LINES 1 FT APART IN ELEVATION

7516 RIVER CIRCLE

15 APR 93

E. [illegible]

MIDDLE LINE -	3FT HEAD	5/16 .59cm x 14 [illegible]	73cm
LOWER LINE	4FT [illegible]	[illegible] .59cm x 14 [illegible]	97cm
UPPER LINE	2FT HEAD	3/16 .39cm x 14 HOOKS	82cm
			20.5cm

TACKLE FOR :

DEEP [illegible] ATTRACTION [illegible] FOR WILD [illegible]

SYSTEMS ; COOGEE [illegible] ; WIDE SEAGAR ; [illegible]

3/24/88 Paid $100.00 ck# 15497 Sud

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 19943
TC: 023-085-18
SERIAL: Nº 14703
☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 7516 (STREET NO) RIVER CIRCLE (STREET) ② FILE: 19943
③ JURISDICTION: MECK. ④ TAX PARCEL NO.: 023-085-18
⑤ SUBDIVISION: RIVERVIEW ACRES EXTEN. ⑥ LOT: 415 ⑦ BLOCK: K

OWNER

⑧ NAME: DONALD (FIRST) E (MIDDLE) JONES (LAST)
⑨ MAILING ADDRESS: 300 IVERSON WAY
⑩ CITY: CHARLOTTE ⑪ STATE: NC ⑫ ZIP: 28203
⑬ PHONE: (WORK) ⑭ (HOME) 704/527-4573

REQUEST

This request is for a(n):

⑮ ☑ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home
㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3
㉓ Maximum occupancy? 6
㉔ Basement? ☐ yes ☑ no
㉕ Type?
㉖ Maximum number of employees?
㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☑ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Donald E Jones
Date: 4-21-88

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUN[TY] DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Departme[nt] has approved the Request for the Job Location contained in this docume[nt]. This approval is granted in accordance with the provisions of Laws & Rules For Sanitary Sewage Collection, Treatment And Disposal in effect [at] the time of issuance of the permit and is subject to the following provisio[ns]: . . . No work shall be conducted on the septic tank system until Installation, Construction, Alteration and, or Repair permit is issued by [the] Department.

. . . This permit is not transferable, and shall become null and voi[d] months from the date of issuance.

Engineering form on file

Environmentalist — Date

Director or Authorized Section Head — 6-28-88 — Date

*This permit must be signed by the Director of Environmental Health o[r] authorized section head in order to be valid.

PROPOSED PLOT PLAN


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 19943

TC: 023-085-18


Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



TRENCH DETAIL
1"=2'-0

NOTES.

1) SHALLOW CONVENTION TRENCHES RUN LEVEL ALONG CONTOUR
2) LEAP SEPTIC SYSTEM 5' FROM FOUNDATION, 10' FROM PROPERTY LINES AND 15' FROM DRY GULLY.



RIVER CIRCLE
60' ROW

Signed: Donald E Jones

Date: 6-17-88

300 Iverson Way
Charlotte NC 28203

REAL ESTATE
BOOK PAGE
5797 0536

10

FILE NO. 19413

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

ACKNOWLEDGEMENT OF REQUEST BY OWNER FOR RECLASSIFICATION OF SITE FROM "UNSUITABLE" TO "PROVISIONALLY SUITABLE" UNDER 10 NCAC 10A .1948(c)

The undersigned, DONALD E. JONES AND WIFE, MARTHA F. JONES,

owner of property located at 7316 RIVER CIRCLE CHARLOTTE, N.C.

("the site") and described in an instrument recorded in Book 5727 at Page 0058, Mecklenburg Public Registry, hereby acknowledges that he applied to the Mecklenburg County Department of Environmental Health ("the Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services at 10 NCAC 10A .1934 et seq; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested pursuant to 10 NCAC 10A .1948(c) that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data and other information which indicate to the Department that the septic tank system proposed by the undersigned can reasonably be expected to function satisfactorily and thus that the findings specified in 10 NCAC 10A .1948(c)(1), (2), and (3) can be made; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further agrees for himself, his heirs and assigns that he shall indemnify and hold harmless the Department, its employees and officials, as well as Mecklenburg County and its employees and officials, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure of said septic tank system.

FEE 6.00
CASH 6.00

The undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

This 27th day of JUNE, 1988.

Donald E. Jones (SEAL)

Martha F. Jones (SEAL)

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, JAMES M. RICHARDSON, a Notary Public for said County and State, do hereby certify that DONALD E. JONES AND MARTHA F. JONES personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 27th day of JUNE, 1988.

My Commission Expires December 11, 1989

James M. Richardson
Notary Public

STATE'S NEW

REAL ESTATE
BOOK PAGE
5797 0537

State of North Carolina, County of Mecklenburg
The foregoing certificate(s) of James M. Richardson

a Notar(y) (ies) Public (is) (are) certified to be correct.
This 28th day of June 19 88.
Charles E. Crowder, Register of Deeds
By: Amy K. Garrett Deputy

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 19943 DATE: 6-26-88

TC: 023-065-19 ☐ L

SERIAL № 11996

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 4-21-88. All work shall be completed on or before 7-26-88, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400' feet

Number of Lines Four

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10' feet

Distance from Well >50' feet

NAME OF OWNER Oenald Jones

LOCATION OF PROPERTY 7516 River Cir.

Comments: Four Trenches 100'x3'x12" Stone ' Keep trenches shallow Micro Flush Toilets to be installed in home

Jim Ervin
Division or Section Head

Jim Ervin
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 19943 DATE: 9-30-88
TC: 023-085-18 ☐ L ☐ CRT
SERIAL № 11410

Name of Owner Donald Jones Juris.:
Address of Property 7516 River Cir

Inspection Data:

Tank Material CC
Total Length of Drainfield 400
Number of Lines 4 @ 100
Cover Depth 6"
Water Supply Source well not in yet
Distance to Water Source keep 250' away
Excavation Inspected 9-28-88
Tank(s) Inspected 9-30-88
Wash Line Inspected —
High Water Alarm Inspected —

PLOT


Design: 1988, 1500ST, mob, 1200SFT, 126, CTR# 79

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☒ installed or constructed ☐ altered or repaired
☒ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☐ Certificate of Completion ☒ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for Three bedroom House

Jim Ervin
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.




FIELD ISOMETRIC

N.T.S.


TABLE 1:
HOLE DATA

LINE #	SIZE	SPACING	#
1	1/8	6.7'	14
2	5/32	6.7'	14
3	3/16	6.7'	14




TRENCH DETAIL

N.T.S.



WASHER TRENCH SECTION

N.T.S.



PUMP TANK DETAIL

N.T.S.

NOTES:

1) PLACE LINE #1 1'-0 BELOW #2, # [illegible] BELOW #3.
2) PUMP: HYDROMATIC SW25M OR EQ.V.
3) INSTALL IN ACCORDANCE WITH [illegible] NCAC

LPP: WASHER LN
75'6 RIVER CIRCLE
SIR # 19943
-C DCB-035-13
MECKLENBURG CO. NC
BY EDDIE RAMSEY [illegible]
12 APR 13

SITE PLAN

1"=30'

