Date Received 6-28-83

MECK COUNTY DEPARTMENT OF
RECEIVED
JUN 28 '83
ENVIRONMENTAL HEALTH

SIR No. 19816
T. C. No. 0152410
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER (formerly - Matthews) Freeman (LAST) Celia (FIRST) Dianne (MIDDLE)

2) ADDRESS OF OWNER 5318 Farm Pond Lane ZIP 28212

3) PHONE NO. Home 563-2622 Office 372-6261


4) LOCATION OF PROPERTY 9924 Janeiro Dr. (STREET OR COUNTY ROAD)

5) SUBDIVISION Brasilia Park LOT NO 10 BLOCK NO D

MAP BOOK NO 15 PAGE NO 79

6) DEED REFERENCE DEED BOOK 3072 PAGE NO 249

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Dianne Freeman
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 5115

SIR No. 19816

Date Issued 7-18-83

T C No. 015-214-10

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Freeman, (LAST) Celia (FIRST) D. (MIDDLE)

ADDRESS OF OWNER 5318 Farm Pond Lane Charlotte, NC ZIP 28212

LOCATION OF PROPERTY 9924 Janeiro Drive (STREET OR COUNTY ROAD)

SUBDIVISION Brasilia Park LOT NO 10 BLOCK NO. D



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The soil investigation was conducted on that portion of the lot as indicated on the above plat. **Provisionally Suitable**

The permeability rate determined by the investigation was . The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the said system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings and the wastewater treatment system on the said lot.
2. The size of the septic tank and wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. The application and installation of the system is limited to the immediate area indicated as acceptable for system installation on the above plat.
4. This approval is void if any grading, filling or construction including the setting of the lot in which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

W. B. Ramsey
Soil Scientist

EHD-S-76

Environmental Health Director or
Authorized Section Head

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19816

T.C. NO. 015-214-10

(Ground Absorption Sewage Disposal)

OWNER: Dianne Freeman
ADDRESS: 5318 Farm Pond Lane 28212
LOCATION OF SITE: 5 Aheine Dr.

PLAT NO:
LOT SIZE: 20,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-4 U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) Clayey U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 40-48 U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) None U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) Adequate U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	TVa			
9. SITE CLASSIFICATION	Acceptable			
10. SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: W. B. Ramsey
Title: Sanitarian

Date: 7-14-83

EHD 539 (Revised: 6/82)

#


101
Cecil
2-4
Pisurtable
199
Jamaino Drive