Date Received 2-19-73

APT No. 5595

T C. No 135-255-05

Map Date 5-9-74

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Bob McLemore & Co. Inc
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 1129 Lebanon Rd ZIP

3) PHONE NO Home Office 545-4507


4) LOCATION OF PROPERTY Pine Lake Lane
(STREET OR COUNTY ROAD)

5) SUBDIVISION Fairwood III LOT NO 77 BLOCK NO. 4

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203 Telephone 374-2113

Date Issued
1. 2-23-73
2. _____
3. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. 5595
T.C. No. ~~135-361-06~~ 135-355-05
5-9-74

NAME OF OWNER Kelmore & Co., Inc.

ADDRESS OF OWNER 2128 Lebanon Road ZIP _____

LOCATION OF LOT Pinelake Lane Fernwood VI 17-H

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	2-22-73	33 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Nora R. Ward
Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70

Serial No. [illegible]99

PTR No. 5595 [illegible]55-05

T C. No. 135-351-01

Date Issued April 9, 1973

Map Date 5-4-74

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Bob McLemore & Company, Inc.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 6129 Lebanon Road, Matthews, N.C. ZIP 28105

LOCATION OF PROPERTY Pine Lake Lane
(STREET OR COUNTY ROAD)

SUBDIVISION Farmwood VI LOT NO 17 BLOCK NO H



PLOT PLAN

This is to certify that a percolation test has been run and on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the grading of roads) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John R. Atkisson

Director, Environmental Health Division or Authorized Section Head

FORM NO E-2-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 4-26-73

ICAR(S) Application No. 5595

T C No. 135-~~355-05~~ 355-01

Map Date 12-15-72 5-9-74


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1. ✓ Install or Construct 2. ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3. PLOT PLAN ACCURATELY DIMENSIONED

4. No. Rooms 3
5. Bedrooms Max No
Employees
6. Washing Machine ✓ Yes ___ No
7. Garbage Disposal Yes ___ No
8. Dishwasher ✓ Yes ___ No
9. Water Supply
A. Individual Well
B. Governmental System
C. Community System
1. Well Size ✓
2. Governmental Size
10. Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within ___ feet of community sewer ___ Yes ✓ No
11. FHA Case No.
12. VA Case No.

13. NAME OF OWNER Bob McLemore & Co., Inc. (LAST / FIRST / MIDDLE)

14. ADDRESS OF OWNER 6129 Lebanon Road

15. PHONE NO. Home ___ Office 545-4507

16. LOCATION OF SYSTEM 7117 Pine Lake Lane (STREET OR COUNTY ROAD)

17. SUBDIVISION Farmwood 6 Lot No. 17-H Block No ___

Map Book No 17 Page No. 81

18. DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19. HAS A PERCOLATION TEST BEEN RUN? X YES ___ NO DATE RUN 4-1-73 PASSED

20. PTR NUMBER (See Instructions) 5595

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

4-25-73
DATE OF APPLICATION

Ingolf Clark, VP
OWNER

FORM NO. E-4-4-(-7)

HEALTH DEPARTMENT'S COPY

Serial No. 2810

LA No 5595

T C No 135-~~331-01~~ 355-05

Map Date 5-9-74 ~~12-19-72~~

Date Issued April 26, 1973

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION EFFLUENT DISCHARGE

NAME OF OWNER Bob McLemore & Company, Inc.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 6129 Lebanon Road, Matthews, N.C. ZIP 28105

LOCATION OF LOT 7117 Pine Lake Lane
(STREET OR COUNTY ROAD)

SUBDIVISION Farmwood 6 LOT NO 17 BLOCK NO H

MAP BOOK NO 17 PAGE NO 81

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/in on an on-site inspection of the said lot and upon the information supplied in the "Application for an Installation Construction, Alteration and or Repair Permit" number 5595 This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed constructed, altred and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Thomas R. Ward — John R Robinson

Environmentalist — Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-4-1-71

HEALTH DEPARTMENT'S COPY

Serial No. 4455

Date Issued 10-11-73

ICAR (S) Permit No. 5595

T. C No. 135

Map Date 5-9-74


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 5595 dated 4-26-73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 11-11-73, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500 gals

Tank Construction Con Conc

Absorption and/or Nitrification Lines:

Total Line Lenght 600'

Number of Lines 6

Distance from House 10'

Distance from Property Line 10'

Distance from Well NA

NAME OF OWNER Bob McLemore & Son

LOCATION OF PROPERTY 7117 Pine Lake Lane (17-14)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: 15' x 100' - Aerobic pit

washer 7½ x 50'

G. M. Herrid & Son

Division or Section Head

Thomas R Ward
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO 6-5-4-1-71

HEALTH DEPARTMENT'S COPY

Serial No. 4515

ICAR (S) Permit No. 5595

Date Issued 6-12-73

T C No. 135-[illegible]

Map Date [illegible]


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application S.F. [illegible], dated 4-26-73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 11-27-73, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500 gal

Tank Construction Concrete

Absorption and/or Nitrification Lines

Total Line Length 60'

Number of Lines 2 @ 5

Distance from House 10'

Distance from Property Line 10'

Distance from Well n/a

NAME OF OWNER Doris M. Stevens

LOCATION OF PROPERTY 7117 Pineville Road

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: [redacted] 12½ x 12

2 @ 12½ x 5

G. M. Shanklin Son

Division or Section Head

Thomas R. Ward
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO E 5-4-1-71

HEALTH DEPARTMENT'S COPY

Serial 4180

C of A (s) No. 55[redacted] 55-05

Date Issued 11-2-73

T C. No 135-[redacted]-01

John R Adkisson

Map Date 12-15-73 5-9-74

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Bob McLemore & Co. (LAST / FIRST / MIDDLE)

Location of Property 7117 Pine Lake Lane

Application Number 5595 Permit Number 5595

Inspection Data:

Liquid Capacity of Tank 1500 gal. Tank Material Pre Cast Co.

Total Length of Drain Tile 600' Number of Lines 6

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source Commwlth Distance from Water Source

Excavation Inspected 11-2-73 (DATE) Tank Inspected 11-2-73 (DATE)

Nitrification Field Inspected 11-2-73 (DATE)

Washing Machine Line Inspected, If Applicable 11-2-73 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ___ installed or constructed, ___ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit (s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: Installed by G.M. Sherrill & Son

Thomas R. Ward

Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY