5

Date Received 4-24-73

APT No. 6092

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Bancroft (LAST) Frank (FIRST) Warren (MIDDLE)

2) ADDRESS OF OWNER 4126 Triangle Drive ZIP 28208

3) PHONE NO. Home 392-1082 Office 392-7379

4) LOCATION OF PROPERTY Marietta Street (STREET OR COUNTY ROAD)

5) SUBDIVISION Hoover Acres LOT NO 445 BLOCK NO. 7


MAP BOOK NO 6 PAGE NO. 200

6) DEED REFERENCE Will Book 13 PAGE NO 381 (J. D. Hoover Estate)

(Bancroft has option to buy from Hoover Estate upon approval of percolation test)

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

(Percolation holes dug toward front of lot 5)



7) ACCURATELY DIAGRAM & DIMENSION LOT

F. W. Bancroft
OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. May 4, 1973
2. _____
3. _____

SDR No. 6082
T.C. No. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Bancroft, Frank Warren

ADDRESS OF OWNER 4128 Triangle Drive ZIP 28209

LOCATION OF LOT Marietta Street, Lot 4 & 5

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	4-2-73	300 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

_____

_____

_____

_____
Environmentalist

(Stencil No.)
MHD 398

FORM NO.
E-19-8-14-70

MECK. COUNTY HEALTH DEPT.
RECEIVED
1974
ENVIRONMENTAL HEALTH DIVISION

T. C. No. 217-121-02 N

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

WELL RECORD

Drilling Contractor Hall Bros — Reg. No. 32 Well Permit No. 6093

1. Town CHARLOTTE NC — County MECK
2. Location Sunnybrook Rd — Quadrangle No. F-68
   Show a sketch of location on back of form
3. Owner Vinson Realty Co
   Address 221 S Church St Char
4. Topography (draw, slope, hilltop, valley, flat) NC
5. Use of Well Home — Date Completed 6-22-71
6. Rig type or method Rotary Air — Total Depth 200
7. Casing: Depth From 0 to 21 ft. — Diam. 6 in. — Type Galv
8. Grout: Depth From 0 to 20 ft. — Material — in. — Method Cement Grout
9. Screen: Depth From — to — ft. — Diam. — in. — Type and Opening
10. Water Zones (depth) 90 ft SCRN
11. Static Water Level: 30 ft. above/below top of casing
    which is — ft. above land surface. Elev. —
    Date 6-22-71
12. Yield (gpm) 5 — Method of testing Air
13. Pumping Water Level: 30 ft. after 4 hrs.
    at 5 gpm.
14. Water Quality — Temperature (°F)
15. Well sterilization method Chlorine
16. Permanent Pump: Type — Make —
    Installed — Date — By —
    Capacity — (gpm) Hp. —
    Intake depth — Airline depth —
17. Remarks: —

I do hereby certify that this well record is true and exact.

Willie Hall
SIGNATURE OF CONTRACTOR OR AGENT

Depth From	Depth To	Formation
0	21	Red Yellow Clay
21	200	Granite

FORM NO. E-22-8-1-72