

11709 ASBURY CHAPEL RD

01935114

5/6/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

Mecklenburg County
Health Department

October 18, 1995

Coldwell Banker Flouhouse, Realtors
Attn: Jo Ann B. Assell
2901 Providence Road
Charlotte, NC 28211

Dear Ms. Assell:

At your request, an investigation was made of the septic tank system and a well water sample was collected on the property located at 11709 Asbury Chapel Road, Huntersville, North Carolina, on October 16, 1995.

The laboratory analysis of the well water sample was reported to be negative for coliform bacteria.

At the time of the investigation there was no effluent apparent on the surface of the ground.

However, it appears as though the well is not the minimum distance of 50 feet from the wastewater treatment and disposal system. According to Laws and Rules for Sewage Treatment and Disposal Systems 15A NCAC 18A .1900, .1950(b) "Ground absorption sewage treatment and disposal systems may be located closer than 100 feet from a private water supply, except springs and uncased wells located downslope and used as a source of drinking water, for repairs, space limitations, and other site-planning considerations but shall be located the maximum feasible distance and in no case less than 50 feet."

If you have any questions concerning this matter, please contact me at 336-5569.

Sincerely,

Susan M. Bateman, R. S.
Individual Water and Wastewater Systems

SB:gf

COLDWELL BANKER

COPY

Pd $5.00 Ck# 3243 10/6/95 OK

FLOUHOUSE,
REALTORS®

2901 PROVIDENCE ROAD
CHARLOTTE, NC 28211
BUS. (704) 366-8791
BUS. (800) 537-3638
FAX (704) 366-8024

Environmental Health Department
Well and Septic Department
700 N. Tryon Street
Charlotte, NC 28202

019-181-02

October 6,1995

Dear Sirs,

Enclosed is a check for $85.00 for Well & Septic inspection for 11709 Asbury Chapel Road,Huntersville, NC 28078.

The property will be closing on or about October 26,1995..

Please forward results ASAP to me at Coldwell Banker Flouhouse, Realtors, 2901 Providence Road, Charlotte, NC 28211.


Thank You.

Sincerely,

Jo Ann B. Assell

Jo Ann B. Assell, Realtor/ Broker
Coldwell Banker Flouhouse, Realtors

2" well ?
washer line appears to be w/in 50' of well



An Independently Owned and Operated Member of Coldwell Banker Residential Affiliates, Inc.

CHAIRMAN'S CIRCLE
Unparalleled Success Through Exceptional Service

APPLICATION FOR AN IMPROVEMENT PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 3266A
TC: _____
SERIAL: № 13248 ☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 11709 (STREET NO.) Asbury Chapel Rd (STREET) ② FILE: _____
③ JURISDICTION: Mech ④ TAX PARCEL NO.: 019-181-02
⑤ SUBDIVISION: _____ ⑥ LOT: _____ ⑦ BLOCK: _____

OWNER

⑧ NAME: Marshall (FIRST) R (MIDDLE) Parks (LAST)
⑨ MAILING ADDRESS: 11709 Asbury Chapel Rd
⑩ CITY: Huntersvill ⑪ STATE: NC ⑫ ZIP: 28078
⑬ PHONE: (WORK) _____ ⑭ (HOME) 875-9350

REQUEST

This request is for a(n):

⑮ ☐ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☒ Other (specify) Carport Deck screen porch

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home
㉑ ☒ Business or place of public assembly
㉒ Number of bedrooms? 3
㉕ Type? _____
㉓ Maximum occupancy? _____
㉖ Maximum number of employees? _____
㉔ Basement? ☐ yes ☒ no
㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Marshall R Parks
Date: 4-22-87

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approve tained in this document. This approv provisions of Laws And Rules For Sa And Disposal in effect at the time of is the following provisions: . . . No wo c tank system until an Installation, ir permit is issued by this Department. . . . This pe icome null and void 36 months from t.

Hold. Wash drain to be repaired. Septic tank under slab?

Environmentalist _____ Date _____

Director or Authorized Section Head _____ Date _____

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.