Date Received 11-1-73

MECK COUNTY HEALTH
RECEIVED
NOV 1 1973
ENVIRONMENTAL HEALTH

APT No. 7193

T. C. No.

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

NAME OF OWNER Quillen (LAST) Robert (FIRST) Wilson (MIDDLE)

ADDRESS OF OWNER P.O. Box 23010 Mint Hill, N.C. ZIP 28212

PHONE NO. Home 545 4249 Office 545 4249


LOCATION OF PROPERTY Karenstone Dr. (off Plaza Rd. Ext.)
(STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. 12 BLOCK NO. 61

MAP BOOK NO 107 PAGE NO. 06

DEED REFERENCE: DEED BOOK 3355 PAGE NO. 077

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



ACCURATELY DIAGRAM & DIMENSION LOT

Robert W Quillen
OWNER

FORM NO. E-1-7-1-70

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203
Telephone 374-2113

Date Issued
1. Nov. 19, 1973
2. _____
3. _____

SDR No. 7193
T.C. No. 107-061-12

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Quillen, Robert Wilson

ADDRESS OF OWNER P.O. Box 23010, Mint Hill, N.C. ZIP 28212

LOCATION OF LOT Karenstone Drive, Lot 12

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	11-16-73	125 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

_____

_____

_____

R. M. Reynolds
Environmentalist

(Stencil No.)
MHD 398
8/70

FORM NO.
E-19-8-14-70