SEE INSTRUCTIONS ON BACK

Date Received 9 24 73

MECK COUNTY HEALTH DEPT
RECEIVED
SEP 24 1973
ENVIRONMENTAL HEALTH DIVISION

Application No 7231

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT


ENVIRONMENTAL HEALTH DIVISION

Application for an

Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1 Install or Construct 2 ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4 No. of bedrooms 3

5 Estimated Max. Emp. Sheet

6 Water, Well No

7 Garbage Disp. Yes No

8 Disposer Yes No

9 Water Use
A
B Ga
C
We
2
Swim
Pool
F Pat
Yes No
Sep
Use No
A Co

131 NAME OF OWNER [illegible] LAST [illegible] FIRST L. MIDDLE

141 ADDRESS OF OWNER [illegible]

151 PHONE NO Home [illegible] Office

161 LOCATION OF SYSTEM 910 Mammoth STREET OR COUNTY ROAD Lake Dr.

171 SUBDIVISION [illegible] Lot No P Block No

Map Book No [illegible] Page No 126

181 DEED REFERENCE — DEED BOOK [illegible] AT PAGE [illegible]

191 HAS A PERCOLATION TEST BEEN RUN? YES NO DATE RUN

201 PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

9-21-73
DATE OF APPLICATION

[signature] L. Thompson
OWNER

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 4391

Date Issued 9-26-73

ICAR(S) Permit No. 7031

T. C. No. _____

Map Date _____


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7031 dated 9-24-73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 10-26-73 after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate [redacted]

Liquid Capacity of Tank —

Tank Construction —

Absorption and/or Nitrification Lines:

Total Line Lenght 100'

Number of Lines 3

Distance from House 10'

Distance from Property Line 10'

Distance from Well 180'

NAME OF OWNER John Dibrell Washburn Et.

LOCATION OF PROPERTY 410 Mammoth Oak Dr.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: 7½' x 33' x 17" stone trench undivided

Division or Section Head

Thomas R. Ward
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO E-5-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 5/20/74 Serial No. [illegible] C of A (s) No 7C31

T C No 187-C21-10

Map Date 6-10-74

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner WARD (LAST) JOHN D. SR. (FIRST, MIDDLE)

Location of Property 4[illegible] HAMILTON CT. [illegible]

Application Number 7C31 Permit Number 7C31

Inspection Data:

Liquid Capacity of Tank [illegible] Tank Material [illegible]

Total Length of Drain Tile 120' + Number of Lines 3

Depth of Filter Material 12" + Cover Depth 15"

Water Supply Source DUG WELL Distance from Water Source 100'+

Excavation Inspected 5/13/74 (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 5/13/74 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been [ ] installed or constructed, [X] altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit as in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments SOIL APPEARS GOOD

R. Cates

[signature] Environmentalist

FORM NO E-6-9-1-72