SEE INSTRUCTIONS ON BACK

111-142-23

Date Received 2-25-84

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
1984

Application No 21260

T. C No. 111-142-23


Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ✓ Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No

4) No of Bedrooms 2
5) Business Use — Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ___ Yes ✓ No
9) Water Supply
A) Individual Well ___
B) Governmental System ✓
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No N/A
12) VA Case No. N/A

13) NAME OF OWNER [illegible] (LAST) [illegible] (FIRST) (MIDDLE)

14) ADDRESS OF OWNER [illegible]

15) PHONE NO. Home ___ Office [illegible]

16) LOCATION OF SYSTEM [illegible] (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK [illegible] AT PAGE [illegible]

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

July 23 84
DATE OF APPLICATION

[illegible]
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

21260


Date Issued 7-30-84 Serial No. 07335 ICAR(S) Permit No. ~~111-142-23~~

T. C. No. 111-142-23

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21260, dated 7-25-84 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 8-28-84, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate repair

Liquid Capacity of Tank ~~PCC~~ 1500g

Tank Construction PCC

Absorption and or Nitrification Lines.

Total Line Length 200'

Number of Lines 3

Distance from House 5'

Distance from Property Line 10'

Distance from Well City Serv.

NAME OF OWNER Grier, Doris H.

LOCATION OF PROPERTY 7801 Boswell Rd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Three Trenches 67' X 3' X 12" Stone

Comments: _____

_____ Division or Section Head

Jim Ericson Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

BHD-S-76

Environmentalist's Department's Copy

Date Issued 8-3-84 **Serial** 6842 C of A (s) No. 21260

T C No 111-142-23 L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Grier (LAST) Davis (FIRST) A (MIDDLE)

Location of Property 7601 Boswell Rd.

Application Number 21260 Permit Number 21260

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material PCC

Total Length of Drain Tile 200 Number of Lines Two

Depth of Filter Material 12" Cover Depth 24"

Water Supply Source City Service Distance from Water Source —

Excavation Inspected 8-3-84 (DATE) Tank Inspected 8-3-84 (DATE)

Nitrification Field Inspected 8-3-84 (DATE)

Washing Machine Line Inspected If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ~~installed~~ or constructed, ~~altered or repaired~~ in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Jim Ellison
Environmentalist

EHO-5-76

ENVIRONMENTAL HEALTH COMMISSION