

2300 ALLEGHANY ST

06112125

1/8/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 53668 DATE: 8/27/03

TC: 061-12-125 ☐ L ☐ CRT

SERIAL 19316

Name of Owner FIRST WESLEYAN CHURCH Juris.: _____

Address of Property 2300 ALLEGHANY ST.

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400'

Number of Lines 4 @ 100'

Cover Depth 18"

Water Supply Source MUNICIPAL


Distance to Water Source N/A

Excavation Inspected 8/27/03

Tank(s) Inspected 8/27/03

Wash Line Inspected N/A

High Water Alarm Inspected N/A



Design 2003, 1500ST, CON, 1200SF, T, 1ZG CTR# AUTRY

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of I5A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of I5A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." *This document shall be null and void if any information contained in the* application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: TYPE II CONVENTIONAL SYSTEM, 4 LINES @ 100', NEW 1500ST & 0-BOX INSTALLED

Dan Smith RS.
Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 5366B DATE: 8/27/03

TC: 061-12-125 L

SERIAL 19469

Permission is hereby given to _____ Install or ~~Construct~~, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, ~~effluent discharge~~ as specified herein at the described location. This permit is granted based upon the information supplied in the application dated _____. All work shall be completed on or before _____, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

SEE O.P.

PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank N/A gallons

Tank Construction PCC

Trench Depth 36"

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Trench Walls Scored and Porous Y

Total Line Length 400 feet

Number of Lines 4

Depth of Stone 12" inches

Distance from House 75 feet

Distance from Property Line 710 feet

Distance from Well N/A feet

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER FIRST WESLEYAN CHURCH

LOCATION OF PROPERTY 2300 ALLEGHANY ST.

Comments: TYPE II CONVENTIONAL SYSTEM, 4 LINES @ 100', 1500ST & D-BOX INSTALLED

Built 1967

Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY