Date Received 11-9-82

SIR No. 19085

T. C. No. 055-164-12

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Ingram (LAST) Michael (FIRST) Kevin (MIDDLE)

2) ADDRESS OF OWNER 3532 Carlyle Dr ZIP 28208

3) PHONE NO. Home 392-7160 Office 333-4181


4) LOCATION OF PROPERTY Little Rock Rd & Delorah. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 12 BLOCK NO. 7

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Michael Kevin Ingram
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SIR. NO. 19085
T. C. NO. 055-164-12
DATE: 11-15-82

Mr. Michael K. Ingram
3532 Carlyle Drive
Charlotte, NC 28208

Re: Property located at Little Rock Road & Delorah Road

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, please submit your proposals, in the form of plans and specifications, to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of a "Septic Tank Agreement Form" provided by this office.

If I may be of assistance, please feel free to call at any time.

Sincerely,

Mike Sexton

Michael A. Sexton
Environmentalist
On Premises Waste Disposal Section

Enclosure

EHD #37 (11-82)

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19085

T.C. NO. 055-164-12

(Ground Absorption Sewage Disposal)

OWNER: Michael Ingram
ADDRESS: 3532 Carlyle Dr. 28208
PLAT NO:
LOT SIZE: 20,000
LOCATION OF SITE: Little Rock Rd & Deloral Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-10 U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clayey (U) 2-1	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) massey (U)	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (24" (U)	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S clay at PS 44 (U)	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS slow (U)	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IIb			
9. SITE CLASSIFICATION	Unsuitable			
10. SOIL SERIES	Iredell			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: W. B. Ramsey
Title: Sanitarian

Date: 11-15-82
+ 12-14-82

EHD 539 (Revised: 6/82)

2/


100
200
Iredell
2-10
24" TO
Saprolite
Deloach Dr
Little Rock Rd
Pine Creek Rd

SEE INSTRUCTIONS ON BACK

Date Received 11-9-82

ICAR (S) Application No. 19085

T. C. No 055-164-12


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes X No
Residence X Yes ___ No
4) No. of Bedrooms 3
5) Business Use — Max No Employees ___
6) Washing Machine X Yes ___ No
7) Garbage Disposal X Yes ___ No
8) Dishwasher X Yes ___ No
9) Water Supply
A) Individual Well ___
B) Governmental System X
C) Community System:
1. Well source ___
2 Governmental source ___
10) Sewage System:
House located within 200 feet of public sewer ___ Yes X No
House located within 200 feet of community sewer ___ Yes X No
11) FHA Case No. ___
12) VA Case No. ___

13) NAME OF OWNER Ingram (LAST) Michael (FIRST) Kevin (MIDDLE)

14) ADDRESS OF OWNER 3532 Carlyle Dr

15) PHONE NO. Home 392-7160 Office 333-4181

16) LOCATION OF SYSTEM Little Rock Rd. (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. 12 Block No. 7

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

11-9-82
DATE OF APPLICATION

Michael K. Ingram
OWNER

EHD-5-76